



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B012692

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: SEPTEMBER 2025

OWNER OF OPERATOR (Co. #133)

NASA/Goldstone
93 Goldstone Rd.
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac. #611)

NASA/Goldstone Deep Space Communications Complex
Goldstone Lake
Fort Irwin, CA 92311

Description:

DIESEL IC ENGINE, PORTABLE, WELDER consisting of: Year of Manufacture 2015, Tier 4, USEPA Family Name FDZXL02.9020, stack height 5' and a stack diameter of 2".

One Deutz, Diesel fired internal combustion engine Model No. TD2.9L4 and Serial No. 11842669, Turbo Charged, Electronic Control Module, Direct Injected, producing 72 bhp with 3 cylinders at 2200 rpm while consuming a maximum of 4 gal/hr. This equipment powers a Miller Welder Model No. 907062-07-01 and Serial No. LC432006, rated at 600 ampere.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.022	gm/bhp-hr
NOx	2.76	gm/bhp-hr
PM10	0.015	gm/bhp-hr
PM2.5	0.015	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.007	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless

Fee Schedule: 1 (b) Rating: 72 bhp SIC: 9661 SCC: 20200102 Location/UTM(Km): 517E/3906N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NASA/Goldstone
93 Goldstone Rd.
Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. This equipment must be moved within this facility or moved to another facility annually. The amount of time that the equipment is kept in the storage location does not count towards the residence requirement so long as the equipment is not set up in an operational configuration.

[Title 17 CCR 93116.2(a)(29)]

3.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel, or CARB diesel fuel utilizing fuel additives, that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

[Title 17 CCR 93116.3(a)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[District Rule 1302(C)(2)(a)]

5.Facility-wide (includes facility nos. 611 and 4402) emissions shall not exceed 80 tons per year of NOx, 24 tons per year of VOC, and 18 tons per year of PM10. Facility-wide emissions shall be calculated and recorded, in tons, on a calendar month basis and totaled for each consecutive twelve-month basis. For emergency engines, only emissions generated during testing and maintenance shall apply toward the facility-wide emission limits. These records shall be maintained as current for a minimum of five (5) years, and made available upon District, State and/or Federal request.

[District Rule 221(B)]

6.The owner/operator shall maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (regular prime use, emergency, testing & maintenance, etc.);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (may use the supplier's certification of sulfur content if it is maintained as part of this log).

[District Rule 1302(C)(2)(a)]

7.This portable, diesel-fired engine is certified to Tier 4 final emission standards and is therefore exempted from the requirements of section 93116.4 of Title 17 CCR 93116. To establish this exemption the Responsible Official (owner/operator) must provide the Certification Statement to the District and CARB when the engine initially satisfies the requirements of section 93116.4(a). This certification statement must list the following for each engine:

- a. The District permit number; and,
- b. The serial number.

Compliance Statements should be sent to the District via mail or electronically to reporting@mdaqmd.ca.gov

Compliance Statements should be mailed to CARB at:

ARB/PERP

P.O. Box 2038

Sacramento, CA 95812

[Title 17 CCR 93116.4(a)and(e)]

8.This unit is subject to the requirements of Title 17 CCR 93116, the Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater.

[Title 17 CCR 93116]

9.A facility wide Comprehensive Emission Inventory Report (CEIR) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

