



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B012748

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2022

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#3280)

NTC Public Works and Building Maintenance
AFZJ-PW-EV, Bldg 602
Fort Irwin, CA 92310

Description:

DIESEL IC ENGINE, PORTABLE PUMP consisting of: A certified Tier 4 Interim Compression-Ignition (Diesel) Portable Prime Use Engine built under the Flexibility provisions of 40 CFR 86, 40 CFR 1039.625, and 13 CCR 2423. EPA Family CDZXL05.4087 with a factory installed Exhaust Gas Recirculation (EGR) system. Exhaust flow is 441 acfm at 1220 degrees Fahrenheit:

One Deutz, Diesel fired internal combustion engine Model No. D 914 and Serial No. 08906156, After Cooled, Direct Injected, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Turbo Charged, Compression-Ignited, producing 69 bhp with 4 cylinders at 2000 rpm while consuming a maximum of 3.74 gal/hr. This equipment powers a Multiquip Pump Model No. MQ600TD80-TLRB and Serial No. 150802, rated at 1600 gpm.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	2.61	gm/bhp-hr
NOx+NMHC	3.28	gm/bhp-hr
PM10	0.200	gm/bhp-hr
PM2.5	0.200	gm/bhp-hr
SOx	0.005	gm/bhp-hr

CONDITIONS:

Fee Schedule: 1 (b)

Rating: 69 bhp

SIC: 7349

SCC: 20200102

Location/UTM(Km): 511E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1.This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 1302]

2.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved for a valid business purpose within this facility or moved to another facility annually.)
[Title 17 CCR 93116.2(bb)]

3.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.
Note: Use of CARB ULSD satisfies this requirement.
[Title 17 CCR 93116.3(a)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[Title 17 CCR 93116.4(c)(2)(A)]

5.The o/o shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) or total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

[Title 17 CCR 93116.4(c)]

6.The fleet* under control of this o/o is subject to and shall comply with the weighted Diesel Particulate Matter (DPM) emission fleet averages** expressed as grams per brake horsepower-hour (g/bhp-hr) of Title 17 CCR Section 93116.3(c) & (d) by the following dates:

// Compliance Date // Weighted DPM (g/bhp-hr)

January 1, 2017 // 0.18

January 1, 2020 // 0.04

===

* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

** The method used to calculate the Fleet Average is found in Title 13 CCR 93116.3(d).

[Title 17 CCR 93116.4]

7.The owner/operator of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and shall include a summary that identifies each portable engine in the fleet, its associated emission rate (expressed in g/bhp-hr), and all other information required by Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7). These Statements of Compliance shall be submitted by the following dates:

// DPM Emission Fleet Average Date // Submit by Date

January 1, 2017 // March 1, 2017

January 1, 2020 // March 1, 2020

===

[Title 17 CCR 93116.4]

8.The owner/operator of fleets that are exempted from the reporting requirements of section 93116.4 pursuant to section 93116.4(a), the Responsible Official shall certify that all portable diesel-fueled engines in the fleet satisfy the requirements of section 93116.4(a). See Title 17 CCR 93116.4(f) for details.
[Title 17 CCR 93116.4]

9.This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

