



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### AUTHORITY TO CONSTRUCT

B012824

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: MAY 2026**

#### **OWNER OF OPERATOR (Co.#457)**

Victor Valley Community College District  
18422 Bear Valley Road  
Victorville, CA 92392

#### **EQUIPMENT LOCATION (Fac.#1127)**

Victor Valley Community College District  
18422 Bear Valley Road  
Victorville, CA 92392

#### **Description:**

BOILERS consisting of: Three (3) identical Raypak Water-Tube Condensing Boilers, Model H7-1503A DHW (Domestic Hot Water) Serial Numbers are noted below, Rated at 1.5 MM Btu/hr Heat Input each; equipped with a Low NOx burner that emit less than 20 ppm NOx, and vents through a stack that is 23 feet high and 8-inch in diameter. Boiler 1, Serial Number: 1709450508 Boiler 2, Serial Number: 1709450542 Boiler 3, Serial Number: 1709450507

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Furthermore, operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued.

[District Rule 1303(B)]

2. This equipment is limited to using only PUC-Regulated pipeline quality natural gas for fuel.

[District Rules 431 and 1303(B)]

3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed unit operating time.

[District Rule 204]

4. The owner/operator shall maintain an operations log for this equipment on-site and current for a minimum of two (2) years, and said

Fee Schedule: 2 (d)

Rating: 4500000 Btu

SIC: 8221

SCC: 10300603

Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Community College District  
18422 Bear Valley Road

Victorville, CA 92392

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

log shall be provided to District personnel on request. The operations log shall include the following information at a minimum:

- a. Total operation time (hours per month and an annual total); and,
  - b. Total fuel consumed on an annual basis: This reading may be a separate reading for this unit only or a combined reading for all six units operating in this building (District Permit Numbers B012824 and B012826).
- [District Rule 1302(C)(2)(a)]

5.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]