



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

B014870

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#88)

NAWS
429 E Bowen Road - Stop 4014
China Lake, CA 93555-6108

EQUIPMENT LOCATION (Fac.#567)

NAWCWD Test Stands
429 E Bowen Road - Stop 4014
China Lake, CA 935556108

Description:

HOT WATER BOILER, NATURAL GAS FIRED (B-1) consisting of: A 2 MMBtu per hour Natural Gas fired AERCO tube-fired boiler, model Benchmark 2000, serial number TBD, equipped with a low-NOx burner.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]
2. This boiler shall only be fueled with utility grade natural gas and shall be equipped with a meter measuring fuel consumption in standard cubic feet. [District Rules 204 and 1303]
3. This boiler must be tuned up at least once every five (5) years. [District Rule 204; 40 CFR 63.7495; 40 CFR 63.7540(a)(12)]

Fee Schedule: 2 (a)

Rating: 2000000 Btu

SIC: 9711

SCC: 10200603

Location/UTM(Km):
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NAWS
Environmental Management Division

China Lake, CA 93555-6108

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. The owner/operator shall maintain an operations log for this boiler current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

(a) Monthly operation in terms of total fuel burned;

(b) Rolling consecutive twelve-month period operation in terms of total hours;

(c) Maintenance and repair actions conducted on the boiler, burner, oxygen trim, and Flue Gas Recirculating systems; and

(d) Results of all boiler tune-ups and tests.

[District Rule 204; 40 CFR 63.10(b)]

5. This boiler shall not be operated for more than 2,080 hours in any consecutive twelve-month period.

[District Rules 204 and 1303]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]