MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

# INACTIVE

C003666

Inactive type Permit has no description information.

## EXPIRES LAST DAY OF: OCTOBER 1997

## OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

## EQUIPMENT LOCATION (Fac.#79)

SVM - Argus Facility
82090 First Street
Trona, CA 93562

**Description:**
BAGHOUSE (BICARB NO. 1 COOLER-PART OF NO. 1 BICARBONATE FLUIDIZED BED DRYER SYSTEM) consisting of: a gas flow of 1954 ACFM at 255 degrees F through a 1 ft diameter stack.

## CONDITIONS:

1. The owner/operator (o/o) shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles which produce minimum emissions of air contaminants.

2. The o/o shall institute a program of maintenance which embraces at least weekly visible emission determinations, monthly visual inspections of all associated equipment (inclusive of the bags and their suspension systems) and regular (to be determined with experience with this unit) measurements of the pressure differential across the bags.

3. The o/o shall log all the items in 2 above in addition to the bag replacements, repairs and non-scheduled maintenance. The log shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.

4. The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.

| Fee Schedule: 7 (h) | Rating: 1 device | SIC: 1474 | SCC: 30504021 | Location/UTM(Km): 465E/3958N |
|---|---|---|---|---|

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

5. This baghouse shall operate concurrently with Bicaarbonate No. 1 Cooler-part of No. 1 Bicarbonate Fluidized Bed Dryer System under valid District permit number B003665.

6. This baghouse shall discharge no more than 0.20 lb/hour at a maximum concentration of 0.02 gr/dSCF at the operating conditions described in the above description.

7. Within 60 days from the initial start-up of this unit, the o/o shall conduct emissions testing in strict accord with all procedures described in the District's Compliance Test Procedural Manual. This testing is necessary to demonstrate compliance with permit conditions in 6 above and District Rules 404 and 405. The District shall be notified no less than 10 working days prior to the test and receive the final test report of emissions no later than 45 days subsequent to the final day of on-site sampling and measurement.