MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

C003673

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JULY 2027

OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#79)

SVM - Argus Facility
82090 First Street
Trona, CA 93562

Description:
BAGHOUSE (MONO FB NO. 1 DRYER-DEHYDRATOR) consisting of: Mono No. 1 Dryer-Dehydrator - part of No. 1 Monohydrate Fluidized Bed Dryer System (B003672) with the following specifications: Exhaust Fan: 250 hp Stack: 8.0' dia & 77' and 211 degrees F at 92,930 acfm & 1850 ft/min NOTE: This process and control(s) are an affected facility under 40 CFR 60, Subpart OOO and commenced construction, modification, or reconstruction after August 31, 1983, but before April 22, 2008.

CONDITIONS:

1. This equipment, and the equipment covered by the following valid permits, shall not emit to the atmosphere PM10 (at a 0.85 fraction of TSP) in excess of 115 tons per year combined (verified through source tests and production records on a rolling twelve month summary basis): C000126, C000127, C000527, C000529, C000532, C000533, C000539, C000543, C000544, C000545, C000548, C000549, C000552, C000553, C000556, C002354, C002355, C003533, C003534, C003667, C003668, C003669, C003670, C003673, C003675, C003676, C003677, C004542, C004543, C004544.
[District Rule 1303(B) - Offsets]

2. This baghouse shall not discharge into the atmosphere an exhaust stream that exhibits greater than seven (7) percent opacity.
[40 CFR 60.672(a) - Table 2]

Fee Schedule: 7 (h)	Rating: 1 device	SIC: 1474	SCC: 30504099	Location/UTM(Km): 465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

3. The maximum grain loading in the stack of this baghouse shall not exceed 0.022 grains per dscf and the emission of particulates (PM) shall not exceed 13.71 pounds per hour.
[40 CFR 60.672(a) - Table 2]

4. The owner/operator shall operate/maintain this equipment in strict accord with recommendations of the manufacturer and/or sound engineering practices.
[District Rule 204]

5. The operating instructions shall be immediately available for use by the operator and provided to District, state or federal personnel upon request.
[District Rule 204]

6. This equipment shall be operated concurrently with the Monohydrate Fluidized Bed Dryer System No. 1 covered in District permit B003672.
[District Rule 204]

7. The owner/operator shall conduct a minimum program of inspection and maintenance on this equipment. The owner/operator shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:
(a) Daily reading of baghouse pressure drop (date and value);
(b) Monthly baghouse stack observation date and result (using USEPA Method 22, and USEPA Method 9 when visible emissions are detected), as outlined in condition 10;
(c) Annual bag and bag suspension system inspection (date and results);
(d) Date of bag replacements, and
(e) Date of any excursion, a description of corrective action, and proof of reporting as required by condition 9.
[District Rule 204; 40 CFR 64]

8. The owner/operator shall conduct compliance tests, at least once every twelve months, relative to District Rules 404 and 405 and to establish PM10 emissions at a 0.85 fraction of TSP (lb/ton of throughput).

The owner/operator must submit a compliance/source test protocol at least thirty (30) days prior to the compliance/source test date. The owner/operator must conduct all required compliance/source tests in accordance with a District-approved test protocol. The owner/operator must notify the District a minimum of ten (10) days prior to the compliance/source test date so that an observer may be present. The final compliance/source test results must be submitted to the District within forty-five (45) days of completion of the test. All compliance/source test notifications, protocols, and results may be submitted electronically to reporting@mdaqmd.ca.gov
[District Rules 404, 405, and 1303(B)]

9. The pollutant-specific emissions unit (B003672), for which this baghouse controls is subject to the requirements of Compliance Assurance Monitoring (CAM) of 40 CFR 64. As such this permit unit must be in compliance with an approved CAM Plan. An excursion of the CAM Plan is defined as a differential pressure outside the range of 2 to 6 inches of column; and/or, the presence of visible emissions, as demonstrated by condition 10. Any excursion of the CAM Plan requires the owner operator to do the following:
(a) Inspect the affected equipment,
(b) Initiate a corrective action, within 24 hours; and,
(c) Report/Document the excursion in the log book required under condition 7.
[40 CFR 64.7(d)]

10. The owner/operator must conduct monthly 6-minute visible emissions inspections using EPA Method 22. The Method 22 test shall be conducted while the baghouse is operating. The test is successful if no visible emissions are observed. If any visible emissions are observed, the owner/operator of the affected facility must initiate corrective action within 24 hours to return the baghouse to normal operation. The owner/operator must record each Method 22 test, including the date and any corrective actions taken, in the logbook required under condition 7.
[40 CFR 64.7(a)]