MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C003890

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2000

OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#79)

SVM - Argus Facility
82090 First Street
Trona, CA 93562

Description:
BAGHOUSE consisting of: Manufactured by Mikro-Pulsaire model 64S-10-20 and serving the Soda Ash Truck Loadout (East) system (B003889) with the following specifications: Bags: 64 w/each 10' x 4 1/2" A/C Ratio: 4.51 x 1 Exhaust Fan: 10 hp Rotary Airlock: 0.5 hp Stack: 15" dia & 60' and ambient temperature at 3,600 acfm & 49'/sec.

CONDITIONS:

1. The maximum grain loading in the stack of this baghouse shall not exceed 0.02 grains per dscf.

2. The owner/operator (o/o) shall operate/maintain this equipment in strict accord with recommendations of the manufacturer and/or sound engineering practices.

3. The operating instructions shall be immediately available for use by the operator and provided to District personnel upon request.

4. This equipment shall be operated concurrently with the Soda Ash Truck Loadout Hopper and Conveyor covered in District permit B003889.

5. The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District Rules. This program shall include, but not be limited to, regular opacity readings,

Fee Schedule: 7 (h)	Rating: 1 device	SIC: 1474	SCC: 99999999	Location/UTM(Km): 465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

pressure differential measurements, and maintenance inspections. Logging of these data shall be required with the log kept on-site for a miimum of two years. This log shall be provided to District personnel on request.

6. Within 60 days of initial start-up, the owner/operator shall conduct a compliance test in accordance with the District Compliance Test Procedural Manual. This test is required to show compliance with permit conditions and Rules 404 and 405. The District shall be notified at least ten working days prior to the test date. The test report shall be submitted to the District within 45 days following the tests.