



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

RENEWAL

C007368

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#1)

CEMEX Construction Materials Pacific LLC
16888 North E Street
Victorville, CA92392

EQUIPMENT LOCATION (Fac.#5)

CEMEX - Black Mountain Quarry Plant
25220 Black Mountain Quarry Road
Apple Valley, CA92307

Description:

MAIN BAGHOUSE (GBH3 - KILN Q3 AND CLINKER COOLER SYSTEM) consisting of: Fuller model 12BHCS336 reverse-air type baghouse with 4,032 Glass bags, each measuring 11.5" diameter x 438" long. Cloth area is 442,853 ft2, air flow is 639,000 ACFM at 485F. Air to Cloth ratio is 1.4:1. Fan motors are rated at 1650 hp. Unit serves Q3 Kiln and Clinker Cooler. Facility has specified that the normal operating range for pressure differential is between 0 and 6 inches water column.

CONDITIONS:

1. The owner/operator (o/o) shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles which produce minimum emissions of air contaminants.

1. The owner/operator (o/o) shall maintain this baghouse in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants.
[District Rule 204]

2. The o/o shall institute a program of maintenance which embraces monthly visual inspections of all associated equipment (inclusive of the bags and their suspension systems) and regular (to be determined with experience with this unit) measurements of the pressure differential across the bags.

2. This baghouse shall be operated concurrently with Q3 Kiln and Clinker Cooler under District Permit B005362.
[District Rule 204]

3. The o/o shall conduct a minimum program of inspection and maintenance on this equipment, following the operations and

Fee Schedule: 7 (h) Rating: 1 device SIC: 3241 SCC: 30500609 Location/UTM(Km): 476E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CEMEX Construction Materials Pacific
LLC
16888 North E Street
Victorville, CA92392

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

maintenance plan requirements pursuant to 40 CFR 63, Subpart LLL. The o/o shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:

- a. A site-specific opacity monitoring plan;
- b. Daily reading of baghouse pressure drop, date and value;
- c. Annual inspection of the bags and bag suspension system;
- d. Monthly baghouse stack observations using USEPA Method 22 (10-minute test). The Method 22 test shall be conducted while the baghouse is operating. The test is successful if no visible emissions are observed. If any visible emissions are observed, the owner/operator of the affected facility must initiate corrective action within 24 hours to return the baghouse to normal operation.
- e. Date and nature of any system repairs.

[40 CFR 63.1350(f), 1355(g), 40 CFR 64.7(d)]

3.The o/o shall log all the items in 2 above in addition to the bag replacements, repairs and non-scheduled maintenance. The log shall be kept current, on-site for a minimum of 5 years and provided to District personnel on request.

4.The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.

4.This baghouse shall be operated in compliance with 40 CFR 63 Subpart LLL - National Emission Standards for Hazardous Air Pollutants from the Portland Cement Manufacturing Industry.

[District Rule 204; 40 CFR 63.1343]

5.The o/o shall install, operate and maintain a continuous emissions measurements and monitoring system as described in the Kiln Q-3 permit under valid District permit B005362. This device shall measure and record those parameters in the units described in that permit.

5.This baghouse shall discharge no more than 0.01 grains/dscf of TSP at the operating conditions given in the above description (BACT). This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.

[District Rule 204 and 1303]

6.This baghouse shall operate concurrently with the Kiln Q-3 and its associated Clinker Cooler, under valid District permit number B005362.

6.The o/o shall install, operate and maintain a continuous emissions measurements and monitoring system as described in the Kiln Q-3 permit under valid District permit B005362. This device shall measure and record those parameters in the units described in that permit.

[District Rule 204]

7.This baghouse shall discharge no more than 727 lb/day on a 30-day rolling average basis, pursuant to the operating conditions described above.

7.This baghouse shall discharge no more than 727 lb/day on a 30-day rolling average basis, pursuant to the operating conditions described above.

[District Rule 204]

8.Opacity measurements shall not exceed 10% aggregated for more than 30 minutes in any 1-hour period.

8.This baghouse shall not discharge into the atmosphere an exhaust stream that exhibits greater than ten percent opacity.

[District Rule 401; 40 CFR 63.1343(b), 1345]

9.The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.

[District Rules 204 and 1203]

10.The o/o shall install and maintain a device which measures the pressure differential across the bags if one has not been provided with this unit.

[District Rule 204]

11.The pollutant-specific emission unit (B005362), for which this baghouse controls is subject to the requirements of Compliance Assurance Monitoring (CAM) of 40 CFR 64. As such, this permit unit must be compliant with an approved CAM Plan. An excursion of the CAM Plan is defined as a differential pressure outside the range of 0 and 6 inches of column; and/or the presence of visible emissions, as demonstrated by condition 3(d) of this District Permit. Any excursion of the CAM Plan requires the owner operator to do the following:

- a. Inspect the affected equipment;
- b. Initiate a corrective action, within 24 hours; and
- c. Report/Document the excursion in facility recordkeeping required under condition 3 of this District Permit.

[40 CFR 64.7(d)]

12.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; 40 CFR 51, Subpart A]