



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C007812

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2011

OWNER OF OPERATOR (Co.#1390)

Granite Construction Co - Indio
38000 Monroe St
Indio, CA 92203

EQUIPMENT LOCATION (Fac.#2946)

Granite Const - Var Loc MDAQMD
District Wide
MDAQMD, CA 92392

Description:

BAGHOUSE consisting of: a Gencor, UltraFlow, model CFP-182. This unit is powered by an approximate 300 hp motor driven fan. This unit has an air:cloth ratio of 4.9::1 and an air flow of approximately 89,000 ACFM. This system includes three internal screw conveyors, each driven by a 7.5 hp motor.

CONDITIONS:

1. The owner/operator, (o/o), shall install, operate and maintain this equipment in strict accord with recommendations of the manufacturer and/or sound engineering practices.
2. The operating instructions shall be immediately available for use by the operator and provided to District personnel upon request.
3. This baghouse shall be operated concurrently with the asphalt dryer under valid District permit B007811.
4. The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District Rules. This program shall include, but not be limited to, weekly opacity readings (Method 22 of the baghouse exhaust), quarterly system inspections (including bags and bag suspension systems) and weekly pressure differential measurements. records of the date and result of each observation shall be kept on site for the duration of the project. This log shall be provided to District personnel on request.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 2951

SCC: 30500205

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Granite Construction Co - Indio
38000 Monroe St

Indio, CA 92203

By: **COPY**
Brad Poiriez
Executive Director

5. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.