



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C010012

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2012

OWNER OF OPERATOR (Co.#722)

American Technologies, Inc (Orange)
210 Baywood Avenue
Orange, CA 92865

EQUIPMENT LOCATION (Fac.#1409)

American Technologies Orange (MD)
District Wide
MDAQMD, CA 92392

Description:

NEGATIVE AIR MACHINE consisting of: 2000 CFM Advanced, Serial # RC00038165 with a primary and secondary filters. The HEPA filter is 99.97% efficient for the collection of all particles whose mean diameter is equal to or greater than 0.3 microns.

CONDITIONS:

1. The HEPA filters shall meet UL 585 and UL 900 class 2 requirements.
2. This air filtration unit shall be operated and maintained in strict accord with those recommendations of the manufacturer.
3. This unit may, at the discretion of the owner/operator, be used on any asbestos project in the District with proper 10-day notification consistent with 40 CFR61. Proper notification is written and telephone communication a minimum of 10 district working days prior to actual placement of the unit at the new site.
4. During full containment projects, view ports shall be provided for inspection purposes. The view port dimensions shall be at least 18 inches square and the bottom of said port no less than 3 to 4 feet from the floor level.
5. Viewing ports shall be sufficient in number to allow observation of all stripping and removal of asbestos containing materials (ACM).

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1795

SCC: 31100202

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

American Technologies, Inc (Orange)
210 Baywood Avenue
Orange, CA 92865

By: **COPY**
Eldon Heaston
Air Pollution Control Officer