



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C010826

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2012

OWNER OF OPERATOR (Co.#811)

Janus Corporation
2025 Tandem Way
Norco, CA 92860

EQUIPMENT LOCATION (Fac.#1537)

Janus Corp - MDAQMD
District Wide
MDAQMD, CA 92392

Description:

NEGATIVE AIR MACHINE consisting of: Force Air, Model # 2000, Serial #3773 with three stage filtration. The HEPA filter is 99.97% efficient for collection of all particles whose mean diameter is greater than or equal to 0.3 microns. This unit exhausts at the rate of 1975 CFM.

CONDITIONS:

1. The HEPA Filters shall meet UL585 and UL900 class 2 requirements
2. This air filtration device shall be operated and maintained in strict accord with those recommendations of the manufacturer.
3. This device may at the discretion of the owner/operator, be used on any asbestos removal project in this District consistent with proper notification per Rule 1002(d)(5)(A)(I) and (ii) and upon payment of annually assessed fees per Rule 306
4. During full containment, view ports will be provided for inspection purposes. The view port dimensions will be at least 18" x 18" and at a level not to exceed 3-4 feet from the ground to the bottom of the view port opening.
5. Viewing ports must be sufficient in number to allow observation of all stripping and removal of RACM.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1795

SCC: 31100202

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Janus Corporation
P.O. Box 7726
Norco, CA 92860

By: **COPY**
Eldon Heaston
Air Pollution Control Officer