



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

C010833

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JANUARY 2026

OWNER OF OPERATOR (Co. #1302)

Blythe Energy, Inc
385 N Buck Blvd
Blythe, CA 92225

EQUIPMENT LOCATION (Fac. #2262)

Blythe Energy, Inc.
385 N. Buck Blvd
Blythe, CA 92225

Description:

OXIDATION CATALYST, UNIT 2 consisting of: Oxidation Catalyst System with a catalyst located within the power train covered by B007954. Johnson Matthey, Honeycat, serial number 200cps.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[District Rules 1302(B)(1)(a) and 1303]

[PSD SE 03-01 4/04]

2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[District Rules 1302(B)(1)(a) and 1303]

[PSD SE 03-01 4/04]

3. This equipment shall be operated concurrently with the combustion turbine generator with valid District permit B007954.

[District Rules 1302(B)(1)(a) and 1303]

[PSD SE 03-01 4/04]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 20100201

Location/UTM(Km): 715E/3725N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Blythe Energy, Inc
385 N Buck Blvd

Blythe, CA 92225-3301

By: **COPY**

Brad Poiriez

Air Pollution Control Officer