



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003229

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2021

OWNER OF OPERATOR (Co. #2733)

NextEra Energy Capital Holdings, Inc.
700 Universe Blvd.
Juno Beach, FL 33408

EQUIPMENT LOCATION (Fac. #941)

Resurgence Solar & BESS
41100 Highway 395
Boron, CA 93516

Description:

IC ENGINE, EMERGENCY DIESEL FIRE PUMP (@ SEGS III) consisting of: Cummins Model NTA855F, Serial No. 11346105, number P-107A, 400 hp diesel fueled IC engine driving a fire pump.

CONDITIONS:

1. This emergency, stationary, compression-ignited, internal combustion engine shall be installed, operated and maintained according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [40 CFR 63.6625(e) - Subpart ZZZZ - NESHAP for Stationary Reciprocating Internal Combustion Engines]
2. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.
3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [40 CFR Subsection 63.6625(f)]
4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance [Rule 204; 17 CCR 93115]

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 4911

SCC: 20200102

Location/UTM(Km): 450E/3874N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NextEra Energy Capital Holdings, Inc.
700 Universe Blvd.
Juno Beach, FL 33408

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

5.The hour limits indicated in condition 4, above, do not apply to in-use emergency fire pump assemblies that are driven directly by stationary diesel-fueled CI engines and only operated the number of hours necessary to comply with the testing requirements of National Fire Protection Association (NFPA) 25 "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems," 2002 edition, which is incorporated herein by reference.[17 CCR 93115.3(n)]

6.Owner/operator must meet the following requirements;

- a. Change oil and filter every 500 hours of operation or annually, whichever comes first. O/o may utilize an oil analysis program as described in 40 CFR 63.6625 in order to extend this requirement.
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary; and
- d. Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6603, table 2d]

7.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below: a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and total hours [17 CCR 93115]; and,

d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log) [17 CCR 93115].

e. Records of the occurrence and duration of each malfunction of operation of equipment, including air pollution control and monitoring equipment, the maintenance performed during these malfunctions, and the corrective actions taken to minimize emissions and restore malfunctioning processes and air pollution control and monitoring equipment to its normal operation [40 CFR 63.6655(a)]; and,

f. Maintenance performed on this equipment, inclusive of the requirements of 40 CFR 63, Subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines as listed below. [17 CCR 93115, ATCM for Stationary Compression Engines]

8.The daily emissions limits for SEGS III through VII includes the emissions from this equipment, reference permits B001793, B001802, B001805, B001882 and B001885.

9.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District. The owner/operator shall have such tests performed and the emission limits of 2.9 lb/hr of NO_x, 0.5 lb/hr of CO and 0.1 lb/hr of Particulate shall not be exceeded.