



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E003502

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: DECEMBER 2025

OWNER OF OPERATOR (Co. #970)

Lockheed Martin Aeronautics Co.
1011 Lockheed Way
Palmdale, CA 93599

EQUIPMENT LOCATION (Fac. #984)

Lockheed - Helendale
17452 Wheeler Road
Helendale, CA 92342

Description:

DIESEL IC ENGINE, FIRE PUMP (BLDG 982) consisting of: NewBerry Tanks Inc.

One Caterpillar, Diesel fired internal combustion engine Model No. 3306 DI and Serial No. 64Z04161, producing 302 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 12.0 gal/hr. This equipment powers a FM Centrifugal Fire Pump Model No. 16MCF and Serial No. 246662MF, rated at TBD.

CONDITIONS:

1. This existing, diesel engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants.

[40 CFR 63.6605(a) and (b) and 63.6625(e)]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d) and 40 CFR 63.6625(f)]

3. This equipment shall only be fired on diesel fuel that meets the requirements of CARB Diesel Fuel as defined in 17 CCR 93115.4(a)(8), or an alternative fuel that meets the requirements of 17 CCR 93115.5(a)(2-6), pursuant to the Air Toxic Control Measure for Stationary Compression Ignition Engines. [17 CCR 93115.5(a)]

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 9641

SCC: 20200102

Location/UTM(Km): 473E/3852N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Lockheed Martin Aeronautics Co.
1011 Lockheed Way

Palmdale, CA 93599

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.This equipment shall be limited to emergency use only, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than twenty (20) hours per year for testing and maintenance.
[17 CCR 93115.6(b)(3) and 40 CFR 63.6640(f)(ii)]

5.The hour limits indicated in condition 4, above, do not apply to in-use emergency fire pump assemblies that are driven directly by stationary diesel-fueled CI engines and only operated the number of hours necessary to comply with the testing requirements of National Fire Protection Association (NFPA) 25 "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems," 2002 edition, which is incorporated herein by reference.
[17 CCR 93115.3(n)]

6.The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and hours of operation with documentation of how many hours are spent for emergency operation, including what classified the operation as emergency, and how many hours are spent for non-emergency operation, including what classified the operation as non-emergency. [17 CCR 93115.10(f) and 40 CFR 63.6655(f)]; and,
- b. Monthly and calendar year operation in terms of total hours, both emergency and non-emergency use, classified as described in 'a.' above [17 CCR 93115.10(f)]; and,
- c. Monthly fuel use [17 CCR 93115.10(f)]; and,
- d. Documentation of certified fuel use, as required by condition 3 (may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
- e. Maintenance performed on this equipment, inclusive of the management practice requirements of condition 7 below; and,
- f. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment [40 CFR 63.6640(b) and 63.6655(a)(2)]; and,
- g. Records of all required maintenance performed on the air pollution control and monitoring equipment [40 CFR 63.6655(a)(4)]; and,
- h. Records of actions taken during periods of malfunction to minimize emissions in accordance with condition 1, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation [40 CFR 63.6655(a)(5)].

7.This engine is subject to the requirements of 40 CFR 63, Subpart ZZZZ, and pursuant to this federal regulation, this engine is required to meet the following compliance requirements by May 3, 2013: The owner/operator of this equipment shall demonstrate continuous compliance by committing to a maintenance schedule inclusive of the management practice requirements listed below:

- a. Change oil and oil filter every 500 hours of operation or annually, whichever comes first (source has the option to utilize an oil analysis program pursuant to 40 CFR 63.6625(i) in order to extend the specified oil change requirement.);
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and,
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
[40 CFR 63.6603(a) and 63.6640(a)]

8.If this emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements required by condition 7, or shutting down the engine would pose an unacceptable risk, the management practice can be delayed until the emergency is over, or the risk has been abated. The management practice should be performed as soon as practicable after the emergency/risk has ended. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.
[40 CFR 63.6603(a)]

9.The owner/operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. [40 CFR 63.6625(h)]

10.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.
[District Rule 204]

11.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.This facility shall not emit more than:

- a. 8 tpy of a single HAP;

- b. 20 tpy of any combination of HAP;
- c. 20 tpy of VOC;
- d. 14.9 tpy of PM10; and,
- e. 20 tpy of NOx.

12.To demonstrate compliance with the specified emissions limits, the facility shall calculate:

- a. VOC emissions, calculated on a calendar month basis and totaled for each 12 month calendar year.
- b. NOx emissions, calculated on a calendar month basis and totaled for each 12 month calendar year.
- c. PM10 emissions, calculated on a calendar month basis and totaled for each 12 month calendar year.
- d. HAP emissions, calculated on a calendar month basis and totaled for each 12 month calendar year.

13.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]