



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003682

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2004

OWNER OF OPERATOR (Co.#866)

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#1612)

SCLA - Phantom
18374 Phantom
Victorville, CA 92394

Description:

EMERGENCY IC ENGINE FOR FIRES consisting of: Aurora 2500 gpm centrifugal water pump, S.N. 81-67458 located in building 678, (pumphouse) Unit 1, powered by

One Caterpillar, Diesel fired internal combustion engine Model No. 3306PC and Serial No. 66D47523, producing 100 bhp with cylinders at rpm while consuming a maximum of. This equipment powers a Model No. and Serial No., rated at.

CONDITIONS:

1. This engine shall only be operated to fight fires and for testing, no more than one hour in any one day and in any one week.
2. The fuel used to operate this equipment shall not contain more than 0.05% sulfur on a weight to weight basis.
3. The owner/operator (o/o) shall require analytical results relating to the sulfur content of the fuel delivered by their supplier. The o/o shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.
4. The o/o shall log the starting and stopping times, the "hour meter" reading, and the date each time the engine is operated and copies of fuel delivery including sulfur concentration. This log shall be maintained current, on-site for a minimum of two years and provided to District personnel upon request.
5. The o/o shall comply with all applicable MDAQMD Rules and Regulations.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4581

SCC: 20300101

Location/UTM(Km): 466E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

6.This equipment shall be operated and maintained in strict accord with the manufacturer's recommendations and/or sound engineering principles.