

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

E003687

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2016

OWNER OF OPERATOR (Co. #866)

Southern California Logistics Airport
18374 Phantom

EQUIPMENT LOCATION (Fac. #1612)

SCLA - Phantom 18374 Phantom Victorville,CA92394

Description:

Victorville, CA92394

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: @ Bldg 730, Kato 375 kW(e) electrical generator, Model 300MSS6, S.N. 50399-1, powered by

OneCaterpillar, Diesel fired internal combustion engine Model No.D379A and Serial No.68B552, producing445 bhp with8 cylinders at rpm while consuming a maximum of18.0gal/hr. This equipment powers aGenerator Model No. and Serial No., rated at.

CONDITIONS:

- 1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
- 2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
- 3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.
- 4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.
- 5. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and

Fee Schedule:7 (g)

Rating:1device

SIC:4581

SCC:20100102

Location/UTM(Km):466E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Logistics Airport 18374 Phantom Victorville,CA92394

By: COPY
Brad Poiriez
Air Pollution Control Officer

this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

6. This genset is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (Title 17 CCR 93115). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

7. This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

Page 2 of 2 Permit: E003687 Issue Date: 02/17/2015