



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

E003779

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2000

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA92278-8110

EQUIPMENT LOCATION (Fac.#591)

USMC AGCC
Box 788110, Bldg. 1451
Twentynine Palms, CA922788110

Description:

EMERGENCY ELECTRICITY GENERATOR AT BLDG 1908, WASTEWATER TREATMENT PLANT consisting of: a Perkins, diesel fueled engine driving a generator. The engine is model 825DTW-8E, serial number 3711404H-1 and is rated at approximately 110.6 bhp. The generator is an Empire, serial number 379-159 rated at 82.5 kW(e).

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 8 hours of operation per month.
4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
 - a. Date of each use;
 - b. Duration of each use, in minutes;

Fee Schedule: 7 (g) Rating: 1 device SIC: 9711 SCC: 99999999 Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

6. This unit shall not be operated more than 1000 h/year without the prior written approval of the District.