



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E004441

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2000**

### **OWNER OF OPERATOR (Co.#69)**

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

### **EQUIPMENT LOCATION (Fac.#96)**

SCE - Solar II  
East Santa Fe Road  
Daggett, CA 92327

#### **Description:**

EMERGENCY DIESEL GENERATOR consisting of: Detroit Diesel, Model No. DDA 12V-149T Generator, 1000 BHP, V-12 cylinders, SN 12E4096.

One Detroit Diesel, Diesel fired internal combustion engine Model No. DDA 12V-149T and Serial No. 12E4096, producing 1000 bhp with 12 cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

#### **CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

2. This unit shall be limited to use for emergency power (when commercially available power has been interrupted). The unit may be operated weekly as part of a testing program which does not exceed 60 minutes per week.

3. The owner/operator, (o/o), shall use only diesel fuel whose sulfur concentration is less than 0.05% on a weight per weight basis.

4. The o/o shall maintain a log which, as a minimum contains:

a. Date and length of time the engine is operated.

b. Sulfur content of the fuel. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9711

SCC: 20100102

Location/UTM(Km):  
591E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison  
P.O. Box 5085  
  
Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Executive Director

5. The o/o shall maintain the log current, on-site for a minimum of two years and provide them to District personnel on request.