



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E004565

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: SEPTEMBER 2002**

**OWNER OF OPERATOR (Co.#746)**

Blythe, City of  
440 S Main Street  
Blythe, CA 92225

**EQUIPMENT LOCATION (Fac.#1542)**

Blythe, City of - Dept of Public Works  
440 S Main Street  
Blythe, CA 92225

**Description:**

EMERGENCY GENERATOR consisting of:

One Detroit, Diesel fired internal combustion engine Model No. 8VA-32942 and Serial No. 7083-7305, Direct Injected, Turbo Charged, producing 350 bhp with 8 cylinders at 1800 rpm while consuming a maximum of . This equipment powers a Kato Generator Model No. and Serial No. , rated at 175kW.

**CONDITIONS:**

1. The owner/operator (o/o) shall log the starting and stopping times of the operational periods of this generator, to the nearest minute, and the date.
2. The o/o shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% by weight.
3. The o/o shall log all purchases of diesel fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.
4. The logs shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
5. The o/o is limited to operating this generator to 1.0 hr/wk for test purposes, and for emergency purposes, which is defined as when commercially available power has been interrupted.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9199

SCC: 20100102

Location/UTM(Km):  
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Blythe, City of  
235 N Broadway  
Blythe, CA 92225

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

6. This unit shall not be operated more than 1000 h/year without the prior written approval of the District APCO.