



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E004566

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2004

OWNER OF OPERATOR (Co.#746)

Blythe, City of
440 S Main Street
Blythe, CA 92225

EQUIPMENT LOCATION (Fac.#1542)

Blythe, City of - Dept of Public Works
440 S Main Street
Blythe, CA 92225

Description:

EMERGENCY GENERATOR consisting of:

One Cummins, Diesel fired internal combustion engine Model No. NHRIS and Serial No. 157021, producing 150 bhp with 6 cylinders at 1200 rpm while consuming a maximum of . This equipment powers a General Electric Generator Model No. 5SJ585A1 and Serial No. WM822512G, rated at 100 KW.

CONDITIONS:

1. The owner/operator (o/o) shall log the starting and stopping times of the operational periods of this generator, to the nearest minute, and the date.
2. The o/o shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% by weight.
3. The o/o shall log all purchases of diesel fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.
4. The logs shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
5. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week (up to two hours once per year for annual testing and

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9199

SCC: 20100102

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Blythe, City of
235 N Broadway
Blythe, CA 92225

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

up to four hours once every three years for triennial testing).

6. This unit shall not be operated more than 1000 h/year without the prior written approval of the District APCO.