



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E004954

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2000

OWNER OF OPERATOR (Co.#257)

All American Pipeline, LP
10000 Ming Avenue
Bakersfield, CA 93311

EQUIPMENT LOCATION (Fac.#916)

12 Gauge Lake Station
State Highway 58
Hinkley, CA 92347

Description:

EMERGENCY GENERATOR consisting of:

One Cummins, Diesel fired internal combustion engine Model No. 6BT5.9-G2 and Serial No. 45433697, producing 166 bhp with 6 cylinders at 1800 rpm while consuming a maximum of . This equipment powers a Onan 100 kW Alternator Generator Model No. 100 DGDB and Serial No. , rated at .

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.
4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4612

SCC: 20100102

Location/UTM(Km):
472E/3864N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

All American Pipeline, LP
PO Box 40160
Bakersfield, CA 93384-0160

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

- a. Date of each use;
- b. Duration of each use, in minutes;
- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).