



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E007939

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2016

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#3280)

NTC Public Works and Building Maintenance
AFZJ-PW-EV, Bldg 602
Fort Irwin, CA 92310

Description:

PORTABLE DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: Year of Manufacture: Unknown; Tier 0, Located on 5th Avenue

One Caterpillar, Diesel fired internal combustion engine Model No. 10066TA and Serial No. YDU 721383F, After Cooled, Direct Injected, Turbo Charged, producing 216 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 10.0 gal/hr. This equipment powers a Perkins Generator Model No. D125P2 and Serial No. F2486A/002, rated at 143 kva.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [Rule 204]
2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.) [Title 17 CCR 93116.2(bb)]
3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements. [17 CCR 93116, ATCM for Portable Compression Engines]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 7349

SCC: 20100102

Location/UTM(Km): 511E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [17 CCR 93116, ATCM for Portable Compression Engines]

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit. [17 CCR 93116, ATCM for Portable]

6.The owner/operator (o/o) shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of two (2) years, and for another year where it can be made available to the District staff within 5 working days from the District's request, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Rule 204; ATCM 93116]

7.This genset is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern. [Rule 204]

8.This genset is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern. [Rule 204]

9.This unit shall not be operated in a single location for twelve months or more.

10.This facility shall emit less than the following on a calendar year basis;

Oxides of Nitrogen (NOx) - 25 tons,

Volatile Organic Compound (VOC) - 25 tons,

Particulate Matter less than 10 microns (PM10) - 15 tons, and

Hazardous Air Pollutants (HAP) - 10 tons per year for any single HAP and 25 tons per year for any combination of HAPs.

Compliance shall be demonstrated annually to the District through the submission of a District approved

Comprehensive Emission Inventory Report (CEIR) or other District approved equivalent method. The report shall be submitted to the District upon request. [Rule 204; 1303]