



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E008304

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2025

OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac. #3247)

USMC AGCC - USMC Facilities
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:

DIESEL IC ENGINE, PORTABLE EMERGENCY GENERATOR #4 consisting of: 2000 Model Year, EPA Tier 1, EPA Engine Family YJDXL06.8014. Emission factors listed are from CARB EO UR-4-75.

One John Deere, Diesel fired internal combustion engine Model No. 6068TF250C and Serial No. PE6068T119680, producing 166 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 6.5 gal/hr. This equipment powers a Denyo Generator Model No. DB-1381J and Serial No. 605394, rated at 80 kWe.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.7	gm/bhp-hr
NOx	5.371	gm/bhp-hr
PM10	0.21	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.3	gm/bhp-hr

CONDITIONS:

1. This certified portable diesel internal combustion engine shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted.

Fee Schedule: 7 (g) Rating: 1 device SIC: 9711 SCC: 20300101 Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

with the application for this permit.
[District Rule 1302]

2.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days, excluding time spent at a designated storage site where the engine can NOT be used for emergency use. (This system must be moved for a valid operational reason within this facility or moved to another facility annually.)
[Title 17 CCR 93116]

3.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel, or CARB diesel fuel utilizing fuel additives, that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.
[Title 17 CCR 93116.3(a)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[Title 17 CCR 93116]

5.This engine has been designated as "emergency" pursuant to Title 17 CCR 93116 and is therefore exempt from the fleet requirements of sections 93116.3(c)(1) and 93116.3(c)(2) pursuant to section 93116.3(c)(3)(B). In order to maintain this designation, this engine is limited to use for emergency power, defined as the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility or the failure of a facility's internal power distribution system. In addition, this unit shall be operated no more than 30 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 30 hour per year limit.
[Title 17 93116.2(a)(12); Rule 204 (M&T hours derived from 17 CCR 93115)]

6.In the event that this engine operates for non-emergency use in a calendar year it becomes immediately subject to the requirements of section 93116.3(c)(1) or (c)(2) in the year such use occurs. The responsible official (owner/operator) must submit a District permit application to convert the engine to regular use, subject to the limitations of section 93116.3(c)(6).
[Title 17 CCR 93116.2(a)(23) and 9.3116.3(c)(3)and(5)]

7.The o/o shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
a. Date and location of each use;
b. Duration of each use (in hours per hour timer);
c. Reason for use (testing & maintenance, emergency, required emission testing);
d. Calendar year operation in terms of fuel consumption (in gallons) or total hours; and,
e. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).
[Title 17 CCR 93116]

8.The owner/operator shall not operate this emergency standby diesel-fueled CI engine for non-emergency use, including maintenance and testing, if the engine is located on school grounds whenever there is a school-sponsored activity and/or if the engine is located within 500 feet of school grounds between 7:30 a.m. and 3:30 p.m. on days when school is in session.
[District Rule 204 and 1320]

9.The owner/operator of portable, diesel-fired engines that are exempted from the requirements of section 93116.3(c)(1) and 93116.3(c)(2) pursuant to section 93116.3(c)(3)(B) of Title 17 CCR 93116, must keep and maintain records pursuant to condition 6. The Responsible Official (owner/operator) must provide the following compliance report to the District and CARB by March 1 of each calendar year indicating the following:
a. The permit number of each emergency engine.

Compliance Reports should be sent to the District via mail or electronically to reporting@mdaqmd.ca.gov
Compliance Reports should be mailed to CARB at:
ARB/PERP
P.O. Box 2038
Sacramento, CA 95812

[Title 17 CCR 93116.4(b)and(d)]

10.This USEPA Tier 1 certified engine may not be sold, or offered for sale, to an end user in California on or after January 1, 2020. The sale of engines for resale outside of California is not prohibited.

[Title 17 CCR 93116.3(e)]

11.This unit is subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter From Portable Engines Rated At 50 Horsepower and Greater (Title 17 CCR \S93116). In the event of conflict between these conditions and the ATCM, the more stringent shall govern.

[Title 17 CCR 93116.3 and District Rule 1302]

12.In each calendar year, the actual emissions of this facility shall be less than 20 tons NOx, 20 tons VOC, and 12 tons PM10 (SM80 Emission Rate). O/o shall demonstrate compliance with this limit on an annual basis through the submission of the Comprehensive Emission Inventory Report (CEIR) to the District. Copies of the CEIR(s) must be kept and maintained on-site for at least five years and presented to District personnel upon request. [District Rule 221]