



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## INACTIVE

E008571

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: DECEMBER 2018**

### OWNER OF OPERATOR (Co. #646)

Walmart Inc. c/o APTIM  
8725 Rosehill Road, Suite 450  
Lenexa, KS 66215

### EQUIPMENT LOCATION (Fac. #2546)

Walmart Distribution Center #7033 - Apple Valley  
21101 Johnson Rd  
Apple Valley, CA 92307

#### **Description:**

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified Tier 2 engine, EPA Family 3CPXL15.8ESK, manufactured in 2003 with no exhaust after-treatment device installed.

One Caterpillar, Diesel fired internal combustion engine Model No. CAT3456 ATAAC and Serial No. 3 PG 00527, After Cooled, Direct Injected, producing 764 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 36.0 gal/hr. This equipment powers a Caterpillar Generator Model No. CAT SR4B and Serial No. CER00490, rated at 500 kW(e).

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	8.5	gm/bhp-hr
NOx	6.9	gm/bhp-hr
PM10	0.38	gm/bhp-hr
SOx	0.38	gm/bhp-hr
VOC	1.0	gm/bhp-hr

#### **CONDITIONS:**

1. This existing, diesel engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 204]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4225

SCC: 20100102

Location/UTM(Km): 482E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Walmart Inc. c/o APTIM  
ATTN: Licensing Support

Lenexa, KS 66215

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the definition of CARB Diesel Fuel per 93115.4(a)(8), or an alternative fuel that meets the requirements of 17 CCR 93115.5(a) and (b).

4.This equipment shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance.

[17 CCR 93115.6(b)(3)]

5.The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Date(s) of each use and hours of operation. Include classification of each use as emergency, non-emergency and/or condition 8 exemption use [17 CCR 93115.10(f)]; and,

b. Monthly and calendar year operation in terms of total hours, both emergency and non-emergency use, classified as described in a. above [17 CCR 93115.10(f)]; and,

c. Monthly fuel use [17 CCR 93115.10(f)]; and,

d. Proof that fuel burned in this equipment meets the requirements of condition 3 (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).

6.This equipment may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(b)(1)]

7.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(2)(C)]

8.This engine meets the definition of an existing commercial emergency stationary RICE pursuant to 40 CFR 63, Subpart ZZZZ. Furthermore, this existing commercial emergency stationary RICE is exempt from 40 CFR 63, Subpart ZZZZ per 63.6585(f)(2).

Per this exemption, this existing commercial emergency stationary RICE located at an area source of HAP emissions shall not operate, nor contractually obligate to be available, for more than 15 hours per calendar year for the purposes specified below:

a. Operation for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies, or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.

b. Operation for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

Additionally, per this exemption, this existing commercial emergency stationary RICE located at an area source of HAP emissions shall not operate for non-emergency use as part of a financial arrangement with another entity.

Upon loss of this definition and/or exemption, immediate compliance with 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (NESHAP) is required.

9.This equipment is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (17 CCR 93115).

10.The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.