



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## INACTIVE

E009186

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JULY 2017**

### OWNER OF OPERATOR (Co.#690)

3E Company/Home Depot  
2455 Paces Ferry Road, N.W.  
Atlanta, GA 30339-4024

### EQUIPMENT LOCATION (Fac.#2751)

Home Depot #1844  
15655 Roy Rogers Drive  
Victorville, CA 92392

#### **Description:**

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified Tier II Diesel engine, EPA Family 5JDXL06.8038, manufactured in 2005 with no exhaust after-treatment device installed. This engine does not currently meet the CA Stationary Diesel Engine ATCM for NMHC plus NOx emissions.

One John Deere, Diesel fired internal combustion engine Model No. 6068HF275L and Serial No. PE6068H471054, After Cooled, Direct Injected, Turbo Charged, producing 220 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 10.7 gal/hr. This equipment powers a Kohler Generator Model No. 135REOZJC and Serial No. 2047566, rated at 60 HZ at 1800 rpm.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
NOx	4.33	gm/bhp-hr
PM10	0.1	gm/bhp-hr
VOC	0.3	gm/bhp-hr

#### **CONDITIONS:**

1. This certified stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[40 CFR 63.6640(a) and Table 6, District Rule 204]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 5211      SCC: 20100102      Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

3E Company/Home Depot  
Reg. Dept.  
Carlsbad, CA 92010

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

time.

[17 CCR 93115.10(d); 40 CFR 63.6625(f)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,  
b. A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 53; or,

(ii) A maximum aromatic content of 20 volume percent.

[17 CCR 93114; 17 CCR 93115.5(b); and 13 CCR 2281-2282]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

4.The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) or total hours;

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

5.This engine shall not be operated for more than 11 hours in any rolling consecutive 24 hour period for routine maintenance or testing purposes.

[District Rule 1303]

6.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE NESHAP). In the event of a conflict between these conditions and the ATCM or NESHAP, the more stringent requirements shall govern.

[District Rule 1302]

7.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when primary power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.

[17 CCR 93115.6(a)(3)(1)(c)]

8.The owner/operator shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

[40 CFR 63.6625(h)]

9.The owner/operator shall conduct inspections in accordance with the following schedule. All inspections must occur at least annually regardless of operating hours.

a. Change oil and filter every 500 hours of operation or annually, whichever comes first, or use an oil change analysis program to extend oil change frequencies per the requirements in 40 CFR 63.6625(i);

b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and

c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

The District must be notified within 5 working days of any exceedance of these maintenance intervals, noting the duration, cause, and corrective actions taken.

[40 CFR 63.6630(a), Table 2d, 40 CFR 63.6640(b), and 40 CFR 63.6650(d)]

10.This engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(b)]

11. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.  
[District Rule 204]

12. This engine does not currently meet the NMHC plus NOx emission limits of Title 17 CCR 93115 based on the engine family's CARB Executive Order (EO U-R-004-0207), therefore the facility must perform a source test which demonstrates compliance in order to continue using this engine.

[17 CCR 93115.6(a)(3)]