



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

**E009430**

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JANUARY 2026**

#### **OWNER OF OPERATOR (Co. #993)**

CaSta Dept of Water Resources  
P.O. Box 1187  
Pearblossom, CA 93553

#### **EQUIPMENT LOCATION (Fac. #2816)**

CaSta DWR Site 64  
Amargosa Rd, Check Site # 64  
Hesperia, CA 92345

#### **Description:**

PROPANE IC ENGINE, EMERGENCY GENERATOR consisting of: Facility Elevation: 3480 feet above MSL

One Ford, LPG fired internal combustion engine Model No. C5PF-6005-A S0300 and Serial No. 39504 B-26-HM, producing 70 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 8.0 gal/hr. This equipment powers an Onan Electric Co. Generator Model No. 30.0EK-5DR8/9026A and Serial No. 0470178382, rated at 30 kW.

#### **EMISSIONS RATES**

| Emission Type | Est. Max Load | Unit    |
|---------------|---------------|---------|
| CO            | 0.129         | lbs/gal |
| NOx           | 0.139         | lbs/gal |
| PM10          | 0.005         | lbs/gal |
| SOx           | 0.0004        | lbs/gal |
| VOC           | 0.083         | lbs/gal |

#### **CONDITIONS:**

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 4941      SCC: 20301001      Location/UTM(Km): 465E/3810N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CaSta Dept of Water Resources  
P.O. Box 1187  
  
Pearblossom, CA 93553

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

1.This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(B)(1)(a)]

2.Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[District Rule 1302(B)(1)(a)]

3.This ICE shall only be fired on propane (LPG).

[District Rule 1302(B)(1)(a)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[District Rule 1110.2(E)(1)(a)]

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 100 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 100 hour per year limit.

[District Rule 1302(B)(1)(a)]

6.The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing); and
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours.

[District Rule 1302(B)(1)(a)]

7.A facility wide Comprehensive Emission Inventory Report (CEIR) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]