



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E009652

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: FEBRUARY 2027

OWNER OF OPERATOR (Co. #100)

Metropolitan Water District of So Calif
158000 MWD Road
Parker Dam, CA 92267

EQUIPMENT LOCATION (Fac. #571)

MWD - Gene Pumping Plant
158000 MWD Road
Parker Dam, CA 92267

Description:

PROPANE IC ENGINE, EMERGENCY GENERATOR (BLACK METAL MTN SITE #2) consisting of: with an integral 3-way catalyst by NETT Technologies installed.

One Ford, Propane fired internal combustion engine Model No. WSG-1068 and Serial No. 04TS31295, producing 126 bhp with 10 cylinders at 1800 rpm while consuming a maximum of 313.0 scf/hr. This equipment powers a Cummins Generator Model No. GGHE-60HZ and Serial No. J040709326, rated at 60 kW.

CONDITIONS:

1. This engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 63.6625(e) and 63.6605(a)&(b)]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[40 CFR 63.6625(f)]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4941

SCC: 20201001

Location/UTM(Km):
761E/3798N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif
P O Box 54153

Los Angeles, CA 90054

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. This unit shall only be fired on propane fuel.
[District Rule 1302(C)(2)(a)]

4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 100 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 100 hour per year limit.
[40 CFR 63.6640(f)(2)]

5. The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours;
- d. Maintenance performed on this equipment, inclusive of the management practice requirements of condition 6 below;
- e. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment [40 CFR 63.6655(a)(2)];
- f. Records of all required maintenance performed on the air pollution control and monitoring equipment [40 CFR 63.6655(a)(4)]; and
- g. Records of actions taken during periods of malfunction to minimize emissions in accordance with condition 1, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation [40 CFR 63.6655(a)(5)].

6. This engine is subject to the requirements of 40 CFR 63, Subpart ZZZZ, and pursuant to this federal regulation, this engine is required to meet the following compliance requirements by October 19, 2013:

The owner/operator of this equipment shall demonstrate continuous compliance by committing to a maintenance schedule inclusive of the management practice requirements listed below:

- a. Change oil and oil filter every 500 hours of operation or annually, whichever comes first (source has the option to utilize an oil analysis program pursuant to 40 CFR 63.6625(i) in order to extend the specified oil change requirement.);
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
[40 CFR 63.6603(a) and 63.6640(a)]

7. If this emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements required by condition 6, or shutting down the engine would pose an unacceptable risk, the management practice can be delayed until the emergency is over, or the risk has been abated. The management practice should be performed as soon as practicable after the emergency/risk has ended. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.
[40 CFR 63.6655]

8. The owner/operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply.
[40 CFR 63.6625(h)]

9. The emissions from this facility shall be less than the following limits:

- a. 8 tons per year of any single HAP or 20 tons per year of any combination of HAPs on a 12 month calendar year basis.
- b. 12 tons of PM10 per year calculated on a rolling twelve month summary basis.
- c. 20 tons of NOx per year calculated on a rolling twelve month summary basis.
- d. 20 tons of VOC per year calculated on a rolling twelve month summary basis.
- e. 80 tons of CO per year calculated on a rolling twelve month summary basis.
- f. 20 tons of SOx per year calculated on a rolling twelve month summary basis.

Compliance with this limit shall be verified with an emissions inventory as requested by the District.
[District Rule 1303]

10. This equipment is subject to the requirements of 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (NESHAP).

11. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]