

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

E010383

Inactive type Permit has no description information.

EXPIRES LAST DAY OF:OCTOBER 2007

OWNER OF OPERATOR (Co.#1771)

Solar Partners VIII, LLC HCR1 Box 280 Nipton,CA92364

EQUIPMENT LOCATION (Fac.#3009)

Ivanpah 3 Ca/Nev border at Primm Ivanpah,CA92364

Description:

EMERGENCY GENERATOR consisting of: Year of Manufacture 2008, Tier II

OneCaterpillar, Diesel fired internal combustion engine Model No.3512C and Serial No.tbd, After Cooled, Direct Injected, Turbo Charged, producing 2250 bhp with 16 cylinders at 1800 rpm while consuming a maximum of 105.0 gal/hr. This equipment powers a Caterpillar Generator Model No. and Serial No., rated at.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
СО	2.6	gm/bhp-hr
NOx	4.8	gm/bhp-hr
PM10	0.15	gm/bhp-hr
SOx	0.004	gm/bhp-hr
VOC	0.1	gm/bhp-hr

CONDITIONS:

1.THIS IS A DRAFT PERMIT; THE OWNER/OPERATOR SHALL NOT OPERATE THIS EQUIPEMENT UNTIL THE CALIFORNIA ENERGY COMMISSION HAS FULLY APPROVED THE ASSOCIATED ELECTRICAL ENERGY GENERATING PROJECT.

2. This engine, certified in accordance with 40 CFR Part 89, and after treatment control device (if any) shall be installed, operated and maintained according to the manufacturer's emission-related written instructions. Further, the owner/operator shall change only those emission-related settings that are permitted by the manufacturer. Unless otherwise noted, this equipment shall

Fee Schedule:7 (g)

Rating:1device

SIC:4911

SCC:20100102

Location/UTM(Km):644E/3934N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Solar Partners VIII, LLC HCR1 Box 280 Nipton,CA92364

By: COPY
Brad Poiriez
Air Pollution Control Officer

Page 1 of 2 Permit:E010383 Issue Date:10/29/2025

also be operated in accordance with all data and specifications submitted with the application for this permit. [40 CFR Part 60 Subparts 60.4205, and 60.4211]

- 3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements. [17 CCR 93115; 60.4207(b)]
- 4.A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR \S93115.10(e)(1)]. District and State Only
- 5.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier. [17 CCR 93115] [40 CFR 60 Subpart IIII allowance for DRP streamlined out.]
- 6. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 0.5 hrs per day for a total of 50 hours per year for testing and maintenance. [NSR and 17 CCR 93115] [Hours allowed by 60.42(f) streamlined out.]
- 7.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);
- c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and total hours [17 CCR 93115]; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log.) [17 CCR 93115]
- 8. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (17 CCR \S93115) and 40 CFR Part 60, Subpart IIII (NSPS). In the event of conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

Page 2 of 2 Permit:E010383 Issue Date:10/29/2025