



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E011810

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2014

OWNER OF OPERATOR (Co.#453)

Victor Valley Wastewater Reclamation Authority
20111 Shay Road
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#3446)

VVWRA - Upper Mojave Narrows Site #1
Kemper Campbell Ranch Rd.
Victorville, CA 92345

Description:

DIESEL IC ENGINE, FEMA TEMPORARY EMERGENCY SEWAGE PUMP consisting of: A certified Tier III diesel engine, EPA Family ACPXL18.1ESK, manufactured in 2010 with no exhaust after-treatment device installed, in support of a Federal Emergency Management Agency (FEMA) coordinated sewage pumping project.

One Caterpillar, Diesel fired internal combustion engine Model No. C9 and Serial No. REH00765, Direct Injected, Turbo Charged, Compression-Ignited, producing 300 bhp with 6 cylinders at 2200 rpm while consuming a maximum of 15.3 gal/hr. This equipment powers a Godwin Pump Model No. CD400M and Serial No. tbd, rated at 4000+ gpm.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	1.79	gm/bhp-hr
NOx	2.83	gm/bhp-hr
PM10	0.11	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.15	gm/bhp-hr

CONDITIONS:

1. This certified stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4952

SCC: 20100102

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Wastewater Reclamation
Authority
P.O. Box 370
Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

specifications submitted with the application for this permit. [40 CFR 60.4211(a), District Rule 1302]

2. This engine shall be limited to use for emergency pumping of raw sewage as mandated by FEMA. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance. [17 CCR 93115.6(a)(3)(1)(c)]

3. This engine shall not be allowed to operate past 06/30/2016. [District Rule 1302]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time. [17 CCR 93115.10(d)]

5. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows: (i) A minimum cetane index of 40; or, (ii) A maximum aromatic content of 35 volume percent. [17 CCR 93115.5(a) and 40 CFR 60.4207(b)]

Note: CA Ultra Low Sulfur Diesel (ULSD) fuel meets the cetane and aromatic content requirement of subparagraph 3.b.

6. The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);
- c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and/or total hours;
- d. Fuel sulfur concentration and cetane index, as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
- e. Maintenance performed on this equipment. [17 CCR 93115.10(f)]

7. This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier. [17 CCR 93115.6(c)(1)(C)]

8. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and this ATCM or NSPS, the more stringent requirements shall govern. [District Rule 1302]

9. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request. [District Rule 1302]