



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### AUTHORITY TO CONSTRUCT

E012074

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: NOVEMBER 2025**

#### OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

#### EQUIPMENT LOCATION (Fac. #3247)

USMC AGCC - USMC Facilities  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278

#### Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified Tier III diesel engine manufactured in 2012, EPA Family CJD LXL135.103, with no exhaust after-treatment device installed:

One John Deere, Diesel fired internal combustion engine Model No. 6068HF485A.B and Serial No. PE6068L865509, After Cooled, Direct Injected, Electronic Control Module, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Smoke Puff Limiter, Turbo Charged, producing 315 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 13.0 gal/hr. This equipment powers a Cummins Generator Model No. 180RE0ZJF and Serial No. 3051892, rated at 80 KW.

#### EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.45	gm/bhp-hr
NOx	2.5	gm/bhp-hr
PM10	0.07	gm/bhp-hr
SOx	0.004	gm/bhp-hr
VOC	0.08	gm/bhp-hr

#### CONDITIONS:

1. This certified stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 9711      SCC: 20100102      Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 60.4211(a)]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

b. A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 40; or,

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a) and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies the requirements of subparagraph 3.b above.

4.This engine shall not be operated for more than 14 hours per day (consecutive 24 hour period) for maintenance and testing purposes.

[District Rule 1303]

5.The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and calendar year operation in terms of fuel consumption (in gallons) and/or total hours;

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

6.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7.This equipment shall not be used to provide power during a voluntarily agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.

[17 CCR 93115.6(a)(3)(1)(c)]

10.The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.  
[District Rule 204]