



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

E013276

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2025

OWNER OF OPERATOR (Co. #46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac. #3069)

Victorville SCLA Central Treatment Facility
So 1/2 Sec 14, T6N R5W
Victorville, CA 92392

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: Gen # 2 Year of Manufacture: 2017; Tier 2 Exhaust stack is 9.5 feet high and 10 inches in diameter.

One Caterpillar, Diesel fired internal combustion engine Model No. C18 and Serial No. FST01803, After Cooled, Direct Injected, Turbo Charged, producing 900 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 42.7 gal/hr. This equipment powers a Caterpillar Generator Model No. LC7 and Serial No. T3400214, rated at 600 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.60	gm/bhp-hr
NOx	3.77	gm/bhp-hr
PM10	0.05	gm/bhp-hr
PM2.5	0.05	gm/bhp-hr
SOx	0.01	gm/bhp-hr
VOC	0.08	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4952

SCC: 20200102

Location/UTM(Km): 466E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1.This certified stationary compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 60.4211(a)]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

b. A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 40; or,

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 80.510(c), and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

4.This equipment shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 30 hours per year for testing and maintenance.

[17 CCR 93115.6(b)(3) and 40 CFR 60.4211(e)]

5.The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

a. Date of each use and duration of each use (in hours);

b. Reason for use (testing & maintenance, emergency, required emission testing, etc.);

c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) or total hours;

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment, including all emissions control devices.

[17 CCR 93115.10(f)]

6.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9.In order to remain below the 80% significance threshold for USEPA Major Source designation ("SM-80"), emissions from the entire facility shall not exceed the following limits:

a. Oxides of Nitrogen (NOx): 20 tons per consecutive twelve month period, measured as NO₂;

b. Oxides of Sulfur (SOx): 20 tons per consecutive twelve month period;

- c. Volatile Organic Compounds (VOC): 20 tons per consecutive twelve month period;
- d. Carbon Monoxide (CO): 80 tons per consecutive twelve month period;
- e. Hydrogen Sulfide (H₂S): 8 tons per consecutive twelve month period;
- f. Lead (Pb): 0.48 tons per consecutive twelve month period;
- g. Particulate Matter 10 microns and less (PM₁₀): 12 tons per consecutive twelve month period;
- h. Any single Hazardous Air Pollutant (HAP): 8 tons per consecutive twelve month period; and
- i. All HAPs combined: 20 tons per consecutive twelve month period.

Compliance shall be demonstrated to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEI) or other equivalent and District approved method.

[District Rules 1302 and 1320]

10.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]