



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

TERMINATED

E014286

Terminated type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2025

OWNER OF OPERATOR (Co.#2739)

GR&BE, Inc (dba Lotus, Lotus Cali, Lotus Group)
150 South San Fernando Blvd., #205
Burbank, CA 91502

EQUIPMENT LOCATION (Fac.#4158)

GR&BE, Inc.
2473 West Hobsonway
Blythe, CA 92225

Description:

PROPANE/LPG IC ENGINE, EMERGENCY GENERATOR, CANNABIS consisting of: Engine is an 4-Stroke Rich Burn; 6.8 Liter Displacement; Engine year of manufacture: 2019; Stack is 4.6 feet tall and 0.5 feet in diameter and exhausts at 1100 degrees F, at a Propane flow rate of 830 cfh; 22.6 gph; Natural Gas Flow rate is 2061 cfh. Facility Elevation is 264 feet above sea level.

One Generac, Propane fired internal combustion engine Model No. QT15068KNAC and Serial No. TBD, producing 254 bhp with 10 cylinders at 3600 rpm while consuming a maximum of 830 scf/hr. This equipment powers a Generac Generator Model No. QT150 and Serial No. TBD, rated at 150 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	13.70	gm/bhp-hr
NOx	8.36	gm/bhp-hr
PM10	0.03	gm/bhp-hr
VOC	0.11	gm/bhp-hr

CONDITIONS:

1. This engine, certified in accordance with 40 CFR Part 1048, and after treatment control device (if any) shall be installed, operated and maintained according to the manufacturer's emission-related written instructions. Further, the owner/operator shall change only those emission-related settings that are permitted by the manufacturer. Unless otherwise noted, this equipment shall also be operated in

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 2833

SCC: 20100201

Location/UTM(Km):
712E/3722N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

GR&BE, Inc (dba Lotus, Lotus Cali, Lotus Group)
150 South San Fernando Blvd., #205
Burbank, CA 91502

By: **COPY**
Brad Poiriez
Executive Director

accordance with all data and specifications submitted with the application for this permit.
[40 CFR 60.4231(c), 60.4233(c), 60.4234, and 60.4243(a)(2)(ii)]

2. This unit shall be fired on PUC-regulated pipeline quality natural gas or Propane/LPG only.
[40 CFR 60.4243, District Rule 1302(C)(2)(a)]

3. Engine may operate in response to a planned electrical outage, operate no more than 30 minutes prior to the forecasted outage, and shut down immediately after normal electrical power is restored.
[District Rule 1302(C)(2)(a)]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[District Rule 1302(C)(2)(a)]

5. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in standard cubic feet or gallons) for both fuel types (natural gas and propane) or total hours; and
- d. Maintenance and repair actions, including date and description.

[40 CFR 60.4243(a)(1) and 60.4245(a)(2)]

6. This unit shall not be operated more than 100 hours for non-emergency maintenance and testing in any consecutive 12-month period (1-year). Emergency is defined as an unplanned interruption to normal commercial power.
[40 CFR 60.4243]

7. This engine is subject to 40 CFR 60, Subpart JJJJ - New Source Performance Standard for Stationary Spark Ignition Internal Combustion Engines and these permit conditions. In the event of conflict, the more stringent requirements shall govern.
[District Rule 1302]

8. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]