



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

E014760

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: MAY 2026

OWNER OF OPERATOR (Co. #159)

HH & J Knoll Ent. Inc.
25635 Crucero Rd
Ludlow, CA 92338

EQUIPMENT LOCATION (Fac. #4345)

Ludlow Well Site
0.4 miles E of Exit 50 on I-40
Ludlow, CA 92338

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: An Existing Tier 0 diesel engine, manufactured in 1990. Exhaust flow approximately 460 acfm, at 887 degrees Fahrenheit through a 8 foot high by 0.33 foot diameter exhaust stack. Facility elevation is 1727 feet above MSL.

One Cummins, Diesel fired internal combustion engine Model No. 4BT - 3.9 and Serial No. 44507103, producing 102 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 5 gal/hr. This equipment powers a Onan Generator Model No. 60QSGCB37698B and Serial No. I900348675, rated at 60 KW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	8.5	gm/bhp-hr
NOx	6.9	gm/bhp-hr
PM10	0.4	gm/bhp-hr
SOx	0.0047	gm/bhp-hr
TOG	1.0	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4941

SCC: 20200101

Location/UTM(Km):
576E/3842N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

HH & J Knoll Ent. Inc.
HCR-1 Box 26

Ludlow, CA 92338

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. This existing, diesel engine shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time. [17 CCR 93115.10(d)]

3. This engine shall only be fired on CARB certified ULSD fuel, verified through fuel purchase records or fuel MSDS. [17 CCR 93115.5(b)]

4. This equipment shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 15 hours per day and no more than 50 hours per year for testing and maintenance. Please note there is no limitation on emergency use. [District Rule 1160(B)(1); 17 CCR 93115.4(30) and 93115.6(b)(3); more stringent hour limitation from District Rule 1303 - basis: BACT]

5. The owner or operator shall keep records and prepare a monthly summary that shall list and document the nature of use for each of the following:

- a. Emergency use hours of operation;
- b. Daily and annual maintenance and testing hours of operation;
- c. Hours of operation for all uses other than those specified above;
- d. Fuel purchase records; and,
- e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

6. This engine is subject to the requirements of 40 CFR 63, Subpart ZZZZ, and pursuant to this federal regulation, the owner/operator of this equipment shall demonstrate continuous compliance by committing to a maintenance schedule inclusive of the management practice requirements listed below:

- a. Change oil and oil filter every 500 hours of operation or annually, whichever comes first (source has the option to utilize an oil analysis program pursuant to 40 CFR 63.6625(i) in order to extend the specified oil change requirement.);
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and,
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

[40 CFR 63.6603(a) and 63.6640(a)]

7. If this emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements required by condition 6, or shutting down the engine would pose an unacceptable risk, the management practice can be delayed until the emergency is over, or the risk has been abated. The management practice should be performed as soon as practicable after the emergency/risk has ended. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63.6655]

8. The owner/operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. [40 CFR 63.6625(h)]

9. The owner/operator shall maintain all records for this equipment on-site and current for a minimum of 36 months, and said records shall be provided to District personnel on request. [17 CCR 93115.10(f)]

10. This equipment may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.
[17 CCR 93115.6(b)(1)]

11. This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.
[17 CCR 93115.6(c)(2)(C)]

12. This equipment is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (17 CCR 93115) and 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (NESHAP). In the event of a conflict between these conditions and the ATCM or NESHAPs, the more stringent requirements shall govern.
[District Rule 1302]

13. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]