



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E014938

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2026

OWNER OF OPERATOR (Co.#759)

Palo Verde Healthcare District
250 N First Street
Blythe, CA 92225

EQUIPMENT LOCATION (Fac.#1470)

Palo Verde Hospital
250 N First Street
Blythe, CA 92225

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: Model Year 2021, Certified Tier IV Final, Engine Family MECEXL06.7AAL.

One Cummins, Diesel fired internal combustion engine Model No. QSB7-G9 and Serial No. 74811479, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Selective Catalytic Reduction, Selective Catalytic Reduction, Diesel Oxidation Catalyst, Direct Injected, Turbo Charged, Charge Air Cooler, DEF Dosing System, producing 314 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 15.4 gal/hr. This equipment powers a Cummins Generator Model No. C150D2DRE and Serial No. H210968032, rated at 150 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.00	gm/bhp-hr
NOx	0.10	gm/bhp-hr
PM10	0.01	gm/bhp-hr
PM2.5	0.01	gm/bhp-hr
SOx	0.01	gm/bhp-hr
VOC	0.02	gm/bhp-hr

CONDITIONS:

1. This certified Tier IV Final stationary compression-ignited internal combustion engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 7 (g) Rating: 1 device SIC: 8062 SCC: 20100102 Location/UTM(Km): 725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Palo Verde Healthcare District
250 N First Street
Blythe, CA 92225

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

[40 CFR 60.4211(a)]

2.A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

(a) Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,

(b) A cetane index or aromatic content, as follows:

(i) A minimum cetane index of 40; or,

(ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 80.510(b) and 40 CFR 60.4207(b)]

Note: Use of CARB certified ULSD fuel satisfies the above requirements.

4.The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Date(s) of each use and duration of each use (in hours);

b. Reason for use (regular testing & maintenance, NFPA testing & maintenance, emergency, etc.);

c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) and/or total hours (both emergency and non-emergency use, classified as described in b. above);

d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,

e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 100 hours per year for testing and maintenance excluding compliance source testing. Time required for compliance source testing will not be counted toward the 100 hour per year limit.

[17 CCR 93115.6(b)]

6.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]