



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

G000864

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: OCTOBER 2002**

**OWNER OF OPERATOR (Co.#106)**

BP West Coast Products LLC  
4 Centerpointe Dr.  
La Palma, CA 90623-1066

**EQUIPMENT LOCATION (Fac.#1960)**

ARCO #1026/Prestige Station #5111  
21727 Highway 18  
Apple Valley, CA 92307

**Description:**

GASOLINE DISPENSING FACILITY consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	6
89U	6
92U	4

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
P11	BAL	G-70-

**CONDITIONS:**

Fee Schedule: 6 (N/A)

Rating: 16 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):  
483E/3818N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

BP West Coast Products LLC  
Attn: Becky Stackhouse  
  
Artesia, CA 90702-6038

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.