



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

G001188

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MAY 1998**

**OWNER OF OPERATOR (Co.#53)**

JACO Hill  
PO Box 82515  
Bakersfield, CA 93380-2515

**EQUIPMENT LOCATION (Fac.#683)**

Three Corners Mrk - Jaco Oil  
32687 Highway 18  
Lucerne Valley, CA 92356

**Description:**

GASOLINE DISPENSING FACILITY consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1
89U	1
92U	1

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

**CONDITIONS:**

Fee Schedule: 6 (N/A)

Rating: 14 product-nozzles SIC: 5541

SCC: 99999999

Location/UTM(Km):  
473E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

JACO Hill  
PO Box 82515  
Bakersfield, CA 93380-2515

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
  
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
  
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.