



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G001664

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2002

OWNER OF OPERATOR (Co. #143)

7-Eleven, Inc
3200 Hackberry Road
Irving, TX 75063

EQUIPMENT LOCATION (Fac. #929)

7-Eleven Store #26388
14665 Bear Valley Road
Hesperia, CA 92345

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

| Tank No. | Material Stored | Volume (US Gallons) | Above/Underground |
|----------|-----------------|---------------------|-------------------|
|----------|-----------------|---------------------|-------------------|

DISPENSING EQUIPMENT

| Fuel Type | Quantity |
|-----------|----------|
| 87U | 12 |

VAPOR CONTROL EQUIPMENT

| Type | Equipment Name | Compliance |
|------|----------------|------------|
| PII | AST | G-70- |

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule: 6 (N/A) Rating: 12 product-nozzles SIC: 5541 SCC: 40600603 Location/UTM(Km): 468E/3818N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

7-Eleven, Inc
P.O. Box 711

Dallas, TX 75221-0711

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

- 2.The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on this equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
- 3.Any modification or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
- 4.Once in each twelve month period the owner/operator shall conduct and pass a static pressure decay test and verify that the air-to-liquid (A/L) ratio is 1.10 plus/minus 0.10 in accordance with CARB Executive Order G-70-150-AC.
- 5.These tests shall be conducted in accordance with the District Compliance Test Procedural Manual and the test report received by the District not later than six (6) weeks prior to the expiration date of this permit.