



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
 760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

G002559

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MARCH 2002**

**OWNER OF OPERATOR (Co.#367)**

Samra and Sons, Inc.  
 35858 Ghost Town Road  
 Yermo, CA 92398

**EQUIPMENT LOCATION (Fac.#1096)**

Yermo Shell & Truckstop  
 35858 Ghost Town Road  
 Yermo, CA 92398

**Description:**

GASOLINE DISPENSING FACILITY consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	8,000	Under Ground
2	89U	8,000	Under Ground
3	92U	8,000	Under Ground
4	Diesel	20,000	Under Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	4
89U	4
92U	4
Diesel	12

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance

Fee Schedule: 6 (N/A)      Rating: 12 product-nozzles      SIC: 5541      SCC: 40600603      Location/UTM(Km): 518E/3863N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Samra and Sons, Inc.  
 P.O. Box 396  
 Yermo, CA 92398

By: **COPY**  
 Brad Poiriez  
 Executive Director

PI	CO	G-70-97-A
PII	BAL	G-70-17-AB

**CONDITIONS:**

1. The toll-free telephone number that must be posted is 1-800-635-4617.
  
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
  
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
  
4. A Gasoline Dispensing Facility Dynamic Back Pressure Test and a Leak Test shall be conducted in accordance with District approval methods on the vapor recovery system.
  - a. These tests shall be performed after dispensing the first 60,000 gallons of gasoline following the modification or the placing of the Phase II vapor recovery system in service. Testing shall, in no case be conducted later than 90 days after placing the Phase II vapor recovery system in service.
  
  - b. The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.