

**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE**G002761**

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2001**OWNER OF OPERATOR (Co.#1144)**

Equilon Enterprises c/o Gilbarco Veeder-Root
7300 West Friendly Avenue
Greensboro, NC 27420-2087

EQUIPMENT LOCATION (Fac.#1166)

Tamarisk Shell
17876 Bear Valley Road
Victorville, CA 923925100

Description:

GASOLINE DISPENSING FACILITY consisting of: GASOLINE DISPENSING FACILITY

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	12
89U	12
92U	12

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
P11	BAL	G-70-

CONDITIONS:

Fee Schedule: 6 (N/A)

Rating: 36 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Equilon Enterprises c/o Gilbarco Veeder-Root
P.O. Box 22087/Attn CMS Mailstop F-76
Greensboro, NC 27420-2087

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on this equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modification or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
4. Once in each twelve month period the owner/operator shall conduct and pass a static pressure decay test and verify that the air-to-liquid (A/L) ratio is 1.00 plus/minus 0.10 in accordance with CARB Executive Order G-70-153-AA.
5. These tests shall be conducted in accordance with the District Compliance Test Procedural Manual and the test report received by the District not later than six (6) weeks prior to the expiration date of this permit.