



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G004822

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2004

OWNER OF OPERATOR (Co.#894)

Lenwood Fuel
2824 Lenwood Rd
Barstow, CA 92311

EQUIPMENT LOCATION (Fac.#1652)

Valero Gas
2824 Lenwood Road
Barstow, CA 92311

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
TPN	48

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	AST	G-70-150-AA

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule: 6 (N/A)

Rating: 48 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Lenwood Fuel 2824 Lenwood Rd Barstow, CA 92311
--

By: **COPY**
 Eldon Heaston
 Air Pollution Control Officer

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
4. Once in each twelve month period the owner/operator shall conduct and pass the Vapor Recovery Test Procedures TP-201.3 and TP-201.5 to very compliance in accordance with CARB Executive Order G-70-153-AA.
5. The test report shall be received by the District not later than six (6) weeks prior to the expiration date of this permit.