



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

G014243

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#2717)

UP2 Holdings, LLC
4130 Cover Street
Long Beach, CA 90808

EQUIPMENT LOCATION (Fac.#4137)

Rocket #0263
12905 Hesperia Road
Victorville, CA 92395

Description:

GASOLINE AND E85 DISPENSING FACILITY consisting of: Three underground storage tanks (UST), equipped with OPW Phase I Vapor Recovery System, a Phase II Balance System, a Veeder Root Vapor Polisher and Veeder Root In-Station Diagnostics (ISD). A 12,000 gallon Diesel portion of tank #2 is exempt from permitting, pursuant to MD Rule 219(E)(15)(c)(iii)). Facility Elevation is 2947 feet above sea level.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	20,000	Under Ground
2a	91U	8,000	Under Ground
2b	Diesel	12,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
TPN	16
Diesel	8

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	OPW	VR-102

Fee Schedule: 6 (N/A) Rating: 56 product-nozzles SIC: 5541 SCC: 40600399 Location/UTM(Km): 473E/3816N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

UP2 Holdings, LLC
4130 Cover Street
Long Beach, CA 90808

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

Type	Equipment Name	Compliance
PII	BAL VP	VR-204

CONDITIONS:

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

2.The owner/operator shall maintain a log of all inspections; maintenance and repairs (including ISD alarm and failures); and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

3.Any modification or installation involving exposure of underground storage tank and/or associated piping requires that the District be notified via telephone or via email request to VaporRecoveryTesting@mdaqmd.ca.gov at least 24 hours prior to backfilling. Vapor control piping and fittings must remain exposed until the District has inspected the installation or given approval to complete backfill.

[District Rule 461 - Gasoline Transfer and Dispensing, District Regulation XIII - NSR]

4.The District must be notified when installation of all piping and control fittings is completed. Vapor control piping and fittings must remain exposed until the District has inspected the installation or given approval to complete backfill. Notification may be made via phone, or via email request to VaporRecoveryTesting@mdaqmd.ca.gov

[District Regulation XIII - NSR]

5.The District shall be notified via telephone or via email request to VaporRecoveryTesting@mdaqmd.ca.gov for inspection no later than 10-days after completion of backfill, modification and/or installation of all vapor control piping and control fittings. Upon notification, the District will determine if an inspection of vapor control piping is required or approval will be given to commence gasoline dispensing.

[District Rule 204 - Permit Conditions, District Rule 461 - Gasoline Transfer and Dispensing, District Regulation XIII - NSR]

6.The Enhanced Vapor Recovery (EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders, VR-102 and Order VR-204, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to

VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-102 and VR-204]

7.The annual throughput of gasoline shall not exceed 2,700,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

8.Enhanced Vapor Recovery (EVR), 2-Point Phase I Vapor Control Equipment must be installed and maintained in compliance with CARB Executive Order VR-102. The owner or operator shall perform the required maintenance as specified in ARB-Approved Installation and Maintenance Manual for the Phase I Vapor Recovery System, including PV maintenance, as applicable.

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-102, 40 CFR 63, Subpart CCCCCC]

9.Enhanced Vapor Recovery (EVR), Phase II Vapor Control Equipment, including the ISD system and software, must be installed and maintained in compliance with CARB Executive Order VR-204. The owner or operator shall install, operate and maintain the Phase II Vapor Recovery System including In-Station Diagnostics System as specified in the ARB-approved Installation, Operation and Maintenance Manual for the Phase II Vapor Recovery System including In-Station Diagnostics System.

10. ISD equipment must be installed and maintained in compliance with CARB Executive Order VR-204. Within 2 hours of the first warning alarm the facility shall notify the responsible official and log information relating to the alarm. When the alarm condition persists, the ISD system activates a failure alarm and dispensing is terminated. The ISD equipment must not be reset to allow vehicle fueling to resume until the condition causing the alarm is repaired by an authorized person or as otherwise allowed per the most recent version of CARB's ISD System Alarm Response Policy: <https://www.arb.ca.gov/vapor/advisories/adv405d.pdf>