MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville,CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

M000234

Inactive type Permit has no description information.

EXPIRES LAST DAY OF:AUGUST 2003

OWNER OF OPERATOR (Co.#9)

Searles Valley Minerals Operations, Inc
13200 Main Street
Trona,CA93562

EQUIPMENT LOCATION (Fac.#7)

SVM - West End Plant
80201 Trona Road
Trona,CA93562

Description:
NO. 3 BOILER consisting of:Babcock & Wilcox, natural gas fired, Type FM-103, maximum rating of 165 MMBTU/hr. This boiler is designed to produce 110,000 lb. of steam per hour at 250 psig at a fuel flow rate of 154,000 cuft/hr through Coen MV burners, ring type.

CONDITIONS:

1.This boiler is on cold standby and shall only be fired under the following conditions:
a. Testing and maintenance for periods that shall be limited to a total of 72 hours of operation per six month period.
b. When either boiler No. 1 or No. 4 is shutdown.

2.If the boiler is fired due to a breakdown of either boiler No. 1 or No. 4, the owner/operator shall comply with the provisions of District Rule 430.

3.The District shall be notified in writing if this boiler is to be operated for a planned outage of either boiler No. 1 or No. 4 thirty (30) days in advance. Prior to start-up, written approval by the District is required.

4.Annual compliance testing is not required for this equipment.

5.A log showing the fuel use for this boiler shall be maintained on site for two (2) years and provided to District personnel on request.

Fee Schedule:10 (2f) Rating:165000000Btu SIC:1474 SCC:10200601 Location/UTM(Km):464E/3951N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Searles Valley Minerals Operations, Inc
P.O. Box 367
Trona,CA93592-0367

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

UNOFFICIAL