



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N002414

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co. #46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac. #1060)

Victorville - Golf Maintenance Yard
16201 Pebble Beach Drive
Victorville, CA 92392

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: Facility Elevation is 2909 feet above sea level.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	Diesel	1,000	Above Ground
2	87U	500	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	Pre EVR	G-70-131-A
PII	BAL	G-70-131-A

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 9131

SCC: 40600603

Location/UTM(Km): 471E/3822N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

Type	Equipment Name	Compliance
SL	SL	VR-301

CONDITIONS:

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461(C)(3)(h)]

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461(C)(3)(h)]

2.The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461(E)(1)]

2.The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461(E)(1)]

3.Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.

[District Regulation XIII]

3.Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.

[District Regulation XIII]

4.Pursuant to Executive Order VR-301, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by this Executive Order.

[Executive Order VR-301]

4.Pursuant to Executive Order VR-301, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by this Executive Order.

[Executive Order VR-301]

5. The owner or operator shall conduct and pass the following tests at least once every twelve (12) months using the latest adopted version of the following test procedures:

A. Pressure Decay Tests per CARB test method TP-201.3B,

B. Liquid Removal Test (if applicable) per TP-201.6,

C. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations,

D. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E, and

E.If a FFS PV-Zero P/V vent valve is used, tests shall be conducted with the valve remaining in its installed position on the vent line(s) in accordance with PV-Zero section of the applicable ARB-Approved Installation, Operation and Maintenance Manual.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to

VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 204 and Executive Order VR-301]

5. The owner or operator shall conduct and pass the following tests at least once every twelve (12) months using the latest adopted

version of the following test procedures:

- A. Pressure Decay Tests per CARB test method TP-201.3B,
- B. Liquid Removal Test (if applicable) per TP-201.6,
- C. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations,
- D. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E, and
- E. If a FFS PV-Zero P/V vent valve is used, tests shall be conducted with the valve remaining in its installed position on the vent line(s) in accordance with PV-Zero section of the applicable ARB-Approved Installation, Operation and Maintenance Manual.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov
[District Rule 204 and Executive Order VR-301]

6. The owner/operator shall maintain and operate this equipment in compliance with CARB Executive Order G-70-131-A, with the exception of the exterior coating and P/V valve configuration, which shall be in accordance with Executive Order VR-301.

6. The owner/operator shall maintain and operate this equipment in compliance with CARB Executive Order G-70-131-A, with the exception of the exterior coating and P/V valve configuration, which shall be in accordance with Executive Order VR-301.

7. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.
[District Regulation XIII]

7. The annual throughput of gasoline shall not exceed 480,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.
[District Regulation XIII; CP-206 Section 2.4.6, Table 2-2]

8. The owner/operator shall install, maintain, and operate this equipment in compliance with these permit conditions and 40 CFR Part 63, Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities.

8. The owner/operator shall install, maintain, and operate this equipment in compliance with these permit conditions and 40 CFR Part 63, Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities.

9. A facility-wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), Health and Safety Code 39607 and 44341-44342, 40 CFR 51, Subpart A]