



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N003060

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JANUARY 2010**

**OWNER OF OPERATOR (Co.#504)**

Adelanto, City of  
11600 Air Expressway  
Adelanto, CA 92301

**EQUIPMENT LOCATION (Fac.#1227)**

Adelanto Police Dept HQ  
11613 Bartlett Road  
Adelanto, CA 92301

**Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	0

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
------	----------------	------------

**CONDITIONS:**

1. This GDF is inactive, and hence there shall not be any fuel dispensing into or out of these tanks. Since residual fuel resides within the tanks, yearly testing as required by condition 4 shall be conducted to ensure the tanks are vapor tight within established and acceptable values.

Fee Schedule: 5 (a)

Rating: 6000 gallons

SIC: 9199

SCC: 40600603

Location/UTM(Km):  
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Adelanto, City of  
11600 Air Expressway  
  
Adelanto, CA 92301

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

2. Any modification or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.

3. The vapor vent pipes are to be equipped with pressure relief valves.

4. The owner or operator shall conduct and pass the following tests annually using the latest adopted version of the following test procedures:

a. Pressure Decay Tests per CARB test method TP-201.3B.

b. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

Passing test reports shall be received by the District not later than six (6) weeks prior to the expiration date of this permit.