MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N003206

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 1999

OWNER OF OPERATOR (Co.#508)

Union Pacific Railroad Co
2015 S Willow St. Manager of Env Field Ops
Bloomington, CA 92316

EQUIPMENT LOCATION (Fac.#1250)

Union Pacific - Kelso
RD-1 Kelbaker Road
Kelso, CA 92351

Description:
GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PII	BAL	G-70-

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule: 5 (a) Rating: 10000 gallons SIC: 4013 SCC: 99999999 Location/UTM(Km): 624E/3877N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Union Pacific Railroad Co
2401 E. Sepulveda Blvd.

Long Beach, CA 90810

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

UNOFFICIAL

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on this equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3. Any modification or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.