



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N005102

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2027

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

EQUIPMENT LOCATION (Fac.#855)

SBCo - Needles Maintenance Yard
Airport Road & Hwy 95
Needles, CA 92363

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: Facility located outside the FONA. Facility elevation is 858 feet above MSL.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	10,000	Above Ground
2	Diesel	10,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-132-B

Fee Schedule: 5 (a) Rating: 10000 gallons SIC: 9711 SCC: 40600603 Location/UTM(Km): 718E/3858N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

By: **COPY**
Brad Poiriez
Executive Director

Type	Equipment Name	Compliance
PII	BAL	G-70-132-B
SL	SL	VR-301

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

3. Modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.

ATC Only: The District must be notified when installation of all piping and control fittings is completed. Vapor control piping and fittings must remain exposed until the District has inspected the installation or given approval to complete backfill. Notification may be made via phone, or via email request to reporting@mdaqmd.ca.gov

[District Regulation XIII - NSR]

4. The Pre-Enhanced Vapor Recovery (Pre-EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders VR-301 and Executive Order (EO)G-70-132-B, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461; CARB Executive Orders G-70-132-B & VR-301, Table 3-1]

5. The annual throughput of gasoline shall not exceed 450,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

6. The gasoline vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by Executive Order (EO) VR-301.

[Rule 204; EO VR-301]

7. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Pre-EVR Executive Order (EO) G-70-132-B for Phase I and VR-301 (Standing Loss Control). Additionally, Phase II Pre-EVR System shall be installed and maintained per G-70-132-B with the exception that hanging hardware shall be EVR Balance Phase II type hanging hardware.

[District Rule 461, CARB Executive Orders G-70-132-B & VR-301; CARB CP-206, Table 2-2; 40 CFR 63, Subpart CCCCCC]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]