

**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE**N005197**

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2014**OWNER OF OPERATOR (Co. #1022)**

SBCo Fire Department
157 W 5th St, 2nd Fl, Accounts Payable
San Bernardino, CA 92415-0451

EQUIPMENT LOCATION (Fac. #1980)

County Fire Station 10 - Pinon Hills
9625 Beekley Road
Pinon Hills, CA 92372

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	500	Above Ground
2	Diesel	500	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-116-F
PII	BAL	G-70-116-F

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 500 gallons

SIC: 9224

SCC: 40600603

Location/UTM(Km):
448E/3809N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fire Department
157 W 5th St, 2nd Fl, Accounts Payable
San Bernardino, CA 92415-0451

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617. [Rule 461]
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request. [Rule 204]
3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District. [Rule 204]
4. The gasoline vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by Executive Order (EO) VR-301. [Rule 204; EO VR-301]
5. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures: a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test); b. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E; c. Liquid Removal Test (if applicable) per TP-201.6, and d. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations. The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit. [Rule 204]
6. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures: a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test); b. Liquid Removal Test (if applicable) per TP-201.6, and c. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations. d. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1 E, The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit. [Rule 204]
7. The o/o shall; install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-116-F, with the exception of the exterior coating and P/V valve configuration, which shall be in accordance with EO VR-301. Additionally, hanging hardware must be replaced with VST Balance EVR type hanging hardware during routine equipment change outs. [Rule 204]
8. Exterior coating and P/V valve retrofit shall occur no later than April 1, 2013; records of the retrofit shall be kept on site and available to State and District personnel upon request. [Rule 204]
9. The California Air Resources Board (CARB) has established a timeline for Aboveground Storage Tanks (AST) Enhanced Vapor Recovery (EVR) system implementation. Pursuant to CARB requirements and State mandated retrofits, the o/o shall ensure that this tank meets all the applicable requirements within the designated timeframes. Prior to conducting any modifications, except standing loss retrofits, the o/o shall obtain a District approved Authority to Construct (ATC) Permit. See the following link for AST EVR Timeline: http://o3.arb.ca.gov/vapor/asttimeline_123009.pdf [Rule 204]