



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N008008

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2016

OWNER OF OPERATOR (Co. #681)

General Atomics - LSNC
3550 General Atomics Court
San Diego, CA 92121-1194

EQUIPMENT LOCATION (Fac. #1648)

G A Aeronautical Sys - El Mirage Rd
73 El Mirage Airport Road
Adelanto, CA 92301

Description:

AVIATION STORAGE AND DISPENSING (JET A TRUCK) consisting of: Ford 1985 F-800 Tank Truck with a 100 gallon per minute Blackmer pump.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	Jet A	2,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
Jet A	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-

CONDITIONS:

1. This equipment shall only be used to fuel or defuel aircraft within the El Mirage Airport Facility. Other fueling or defueling activities shall only be performed with the express written consent of the District.

Fee Schedule: 5 (a)

Rating: 2000 gallons

SIC: 3721

SCC: 40600138

Location/UTM(Km): 459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

General Atomics - LSNC
ATTN: LSNC

San Diego, CA 92186-5608

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

2.This equipment shall only store and dispense Jet A fuel or the equivalent.

3.Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted in these conditions.

4.Annual throughput of Jet A fuel or equivalent shall not exceed 2,000,000 gallons. Throughput records shall be kept on site and available to District personnel upon request.