



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N010974

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: DECEMBER 2025

OWNER OF OPERATOR (Co. #866)

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

EQUIPMENT LOCATION (Fac. #3149)

Victorville - SCLA Fuel Farm #2
18373 Gateway
Victorville, CA 92394

Description:

AVIATION FUEL STORAGE AND DISPENSING consisting of: 12,000 gallon capacity tank

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
103	AvG	12,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
AvG	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	N/A	N/A
PII	N/A	N/A

CONDITIONS:

Fee Schedule: 5 (b) Rating: 10000 gallons SIC: 4581 SCC: 40600603 Location/UTM(Km): 464E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Logistics Airport
18374 Phantom
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1.This equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 204]

2.Any modifications or changes to system in its entirety require prior approval from the District. [District Regulation XIII - NSR]

3.The annual throughput of gasoline shall not exceed 100,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

4.This tank shall be used to store aviation gasoline only. MSDS shall be maintained on-site and available and shall be provided to District personnel upon request.

[District Rule 204]

5.Vapor vent pipe is to be equipped with a pressure relief valve set to within 10% of the maximum working pressure of the tank. The maximum pressure of this storage tank is 3.3 PSI.

[District Rule 463]

6.Hatch openings shall not be open more than three minutes for visual inspection and pumping shall be stopped at least three minutes prior to opening a hatch.

[District Rule 461]

7.The fill assembly is to be equipped with a spill bucket and dry break which prevent liquid spillage upon disconnect from exceeding 10 ml.

[District Rule 461]

8.This tank is to be inspected and maintained as follows:

- a. The fill tube is to be equipped with a vapor tight cover with a properly seated and intact gasket;
- b. All dry breaks are to have vapor tight seals and be equipped with vapor tight covers or dust covers;
- c. The fill tube assembly shall prevent vapor leakage from any portion of the vapor recovery system; and,
- d. All tank vapor return pipes without dry breaks shall be equipped with a vapor tight cover with properly seated and intact gasket.

9.The owner/operator shall maintain a log of the following:

- a. Daily log of throughput;
- b. Inspections, repairs and maintenance performed on the tank; and,
- c. Cumulative annual throughput in gallons.

These logs/other documentation shall be maintained on-site and available for two years and shall be made available to District personnel upon request.

[District Rule 461 and 463]

10.The owner/operator shall conduct TP-201.3B - Determination of Static Pressure of Vapor Recovery Systems of Dispensing Facilities with Above Ground Tanks within 60 days of construction completion and once every twelve months thereafter. TP-201.3B has been approved by the Air Pollution Control Officer to determine compliance with fugitive vapor leak and fugitive liquid leak requirements pursuant to Rule 463(C)(3)(a).

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov
[District Rule 463]

11.The emissions from this facility shall be less than the following limits:

- a. 8 tons per year of any single HAP, or 20 tons per year of any combination of HAPs, in any consecutive 12 month period; and,
- b. 20 tons of VOC per year in any consecutive 12 month period.

Compliance with this limit shall be verified with monthly facility emission summaries and a calendar year emission summary. Monthly emissions summaries shall be calculated using a District-approved method, with at least the last two years of monthly emissions summaries maintained and available to be provided to District, State or Federal personnel upon request.

12.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]