



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

N011589

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2013

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA923105085

Description:

GASOLINE DISPENSING FACILITY - NON-RETAIL consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
262AT	87U	5,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-10-A
PII	BAL	G-70-10-A

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-877-723-8070.

[Rule 204] [Rule 461]

Fee Schedule: 5 (a)

Rating: 5000 gallons

SIC: 9711

SCC: N/A

Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA92310

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

2.The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request. [Rule 204] [Rule 462]

3.Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District. [Rule 204]

4.The vapor vent pipes are to be equipped with pressure relief valves.
[Rule 204] [EO G-70-10-A]

5.Pursuant to District Rule 462(D)(3), Organic Liquid Transport (Tank Truck, Trailer, etc.), prior to dispensing any fuel, this tanker truck shall have a valid certification of vapor integrity as defined by the applicable Air Resources Board Certification and Test Procedures, pursuant to Health and Safety Code Section 41962(9) and the California Administrative Code Title 17, Section 94004; see: <http://www.arb.ca.gov/enf/cargotanks/testproc.htm>

6.The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.
[Rule 204]

7.The o/o shall; install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-10-A, and the National Air Toxic Standards for Gasoline Dispensing Facilities (GDF) (40 CFR 63, Subpart CCCCCC). In the event of conflict with these permit conditions and the NESHAP, the more stringent requirements shall govern. [Rule 204]

8.As stated in Title 17 of the California Code of Regulations \S 94014: "Certification of Vapor Recovery Systems for Cargo Tanks," the certification of gasoline vapor recovery systems for cargo tanks shall be accomplished in accordance with CARB's CP-204: "Certification Procedure for Vapor Recovery Systems of Cargo Tanks." Pursuant to this requirement, the owner or operator shall conduct and pass the following tests ANNUALLY, using the latest adopted version of the following test procedures:

See: <http://www.arb.ca.gov/enf/cargotanks/testproc.htm>

- a. TP-204.1, DETERMINATION OF FIVE MINUTE STATIC PRESSURE PERFORMANCE OF VAPOR RECOVERY SYSTEMS OF CARGO TANKS;
- b. TP-204.2, DETERMINATION OF ONE MINUTE STATIC PRESSURE PERFORMANCE OF VAPOR RECOVERY SYSTEMS CARGO TANKS, and
- c. TP-204.3, DETERMINATION OF LEAKS.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

The District shall receive passing test report no later than six (6) weeks prior to the expiration date of this permit.

[Rule 204] [Title 17 of the California Code of Regulations \S 94014]

9.The Owner/Operator shall use this tanker truck for Phase I fuel loading operations only. This equipment is not equipped with Phase II vapor recovery; hence it shall not be used for direct fueling of vehicles such as trucks and automobiles. [Rule 204]